


# Energy Simulation for Commercial Buildings – Trinidad and Tobago August 23-24, 2017



Carrier Corporation  
Software Systems Network  
Carrier University





2012©Carrier Corporation  
Carrier University  
6540 Old Collamer Rd. S.  
East Syracuse, NY 13057  
Phone 800.253.1794 • Fax 315.432.6844  
e-Mail: [software.systems@carrier.utc.com](mailto:software.systems@carrier.utc.com)  
World Wide Web: [www.commercial.carrier.com](http://www.commercial.carrier.com)

ALL RIGHTS RESERVED. No part of this work covered by the copyright hereon may be reproduced or used in any form or by any means—graphic, electronic, or mechanical, including photocopying, recording, taping, Web distribution or information storage and retrieval systems—without the written permission of Carrier Corporation.


For permission to use material from this text contact us by:  
Tel (800) 253-1794  
Fax (315) 432.3871  
e-Mail [software.systems@carrier.utc.com](mailto:software.systems@carrier.utc.com)
















# Workshops 1 & 2



Blank Page



## Workshop 1 Inputs - Create New Project and Link Simulation Weather




Our first workshop focuses on expanding an existing design load analysis to include a complete energy simulation. Our first step is retrieving an archived system design load project developed in the HAP for Load Estimating Basic Training Seminar. The retrieval of this project includes all spaces, air systems and library items so we can focus on the additional input requirements for completing an energy analysis. Take the following steps to begin this workshop.



First open windows explorer, navigate to the class flash drive, find the **"Trinidad Energy"** Folder, **copy the entire folder "1.Unsolved Workshops" to your desktop**. Then launch HAP and create a new project as shown in Figure 1.1 below.

Figure1.1 - Create New Project in HAP



### Setting Project Preferences

Once we create the New Project, HAP prompts us to choose the applicable ventilation standard for the project. This first step in our design process links our project to the appropriate database in determining the ventilation requirements for the spaces and air systems in our project. The choices include:

- User Defined
- ASHRAE 62-2001
- ASHRAE 62.1-2004


- ASHRAE 62.1-2007

After assigning the appropriate ventilation standard, we assign the appropriate Energy Standard. The choices are:

- ASHRAE 90.1-2004
- ASHRAE 90.1-2007 OR 90.1-2010

Please refer to Fig 1.2 below for additional details.

Figure1.2 – Setting Project Preferences



**Select the ASHRAE 62.1-2007 Ventilation Standard, ASHRAE 90.1-2007 Energy Standard and the \$ Dollar Currency Symbol \$ for our workshop and class project.**

Users can set HAP program preferences under the General Tab. Please refer to Figures 1.3 and 1.4 below for additional details of the General HAP program preferences.



Figure 1.3 – HAP Program Preferences





Figure1.4 – View/Preferences



Note: Users can access the Program Preferences anytime by going to the View item on the menu bar and selecting Preferences as shown in Figure1.4



## Enter Design and Simulation Weather Properties


Next, we define the project design weather properties and link the 8760 hour TMY simulation weather file used in energy simulations using one of the following methods. We can assign the defaulted ASHRAE design weather properties by using the "Weather Wizard" or using the Weather Properties input forms. Let's first look at the Weather Wizard.

**Go to the "Wizards" item on the menu bar and select "Weather Wizard."** When selecting the weather wizard, HAP presents the following graphical interface where the user selects the region, location and city either from the drop down or by clicking on the map. Refer to Fig 1.5 and 1.6 below for details.

Figure1.5 – Selecting Weather Wizard




Figure 1.6 – HAP Weather Wizard





Select Region



**PULL  
DOWN  
TRINIDAD &  
TOBAGO  
LOCATION**

Select Region    Select Location    Select City

Choose City

Region: Central & South America    Location: Trinidad & Tobago    City: Port of Spain

OK    Cancel    Help

After accepting the wizard inputs HAP converts the Wizard Data to the HAP interface as shown in Figure 1.8.



## Weather Inputs

Project: Untitled  
Prepared By: carrier

07/23/2017  
10:26 AM

## Weather Inputs


## Port of Spain, Trinidad &amp; Tobago

Region ..... Central & South America  
Location ..... Trinidad & Tobago  
City ..... Port of Spain  
Latitude ..... 10.6 Deg.  
Longitude ..... 61.3 Deg.  
Elevation ..... 49.0 ft  
Summer Design Dry-Bulb ..... 92.8 °F  
Summer Coincident Wet-Bulb ..... 78.0 °F  
Summer Daily Range ..... 13.8 °F  
Winter Design Dry-Bulb ..... 69.1 °F  
Winter Design Wet-Bulb ..... 57.7 °F  
Atmospheric Clearness Number ..... 1.00  
Average Ground Reflectance ..... 0.20  
Local Time Zone (GMT +/- N hours) ..... 4.0 hours  
Consider Daylight Savings Time ..... No  
Simulation Weather Data .TRINIDAD\_TOBAGO\_PORT\_OF\_SPAIN\_ASHRAE\_IWEC2.HW1

Note that you can edit any of the input items in the Design Parameters, Design Temperatures and Design Solar input forms.

One of the enhancements to is the ability for users to import the following simulation weather data formats: ASHRAE IWEC (\*.IWEC), ASHRAE IWEC2 (\*.CSV), Energy Plus (\*.EPW), USA TMY2 (\*.TM2) or USA TMY3 (\*.CSV). See Figure 1.10 Below for additional details.

Figure 1.10 – Importing Simulation Weather Data





THAT EXERCISE SHOWED US HOW TO USE THE WEATHER WIZARD. FOR OUR WORKSHOP WE WILL NOW IMPORT A HAP ARCHIVE WITH THE TRINIDAD WEATHER DATA ALREADY CONFIGURED:

1. OPEN A "NEW" PROJECT. SAY "OK" TO PREFERENCES
2. GO TO 'PROJECT', "RETRIEVE HAP 5.0 DATA"
3. BROWSE TO THE DESKTOP AND YOUR FOLDER "2. CLASS FLASH DRIVE TRINIDAD 2017."
4. DOUBLE CLICK ON THE FOLDER CALLED "1. HAP ARCHIVES LOADS AND ENERGY"
5. HIGHLIGHT AND OPEN "UNSOLVED LOADS AND ENERGY"
6. HIGHLIGHT "TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 "
7. OPEN THEN RETRIEVE IT INTO HAP
8. CLICK "PROJECT" "SAVE AS" AND KEEP THE SAME TITLE

### ***Defining the Holiday Schedule***



In the simulation input form under the simulation tab, configure energy simulation data for the same city. Note that the first day of the year selection defaults to Sunday and determines where the weekends occur. **Please change day of the week for January 1st to Friday.**

Figure 1.11 – Adding Holidays

The next step is adding the following **National Trinidad Holiday dates** to the Holidays List by double left clicking the date on the calendar:

Jan 01  
 Apr 18,21  
 May 30  
 June 14,19  
 July 28  
 Aug 1,31  
 Sep 24  
 Oct 24




Dec 25,26

**Note:** Please remember to “**save early and save often**”

Design and simulation weather reports are displayed on the following pages.  
Use one of the following procedures to preview the weather input details.

1. Weather reports are available by highlighting “weather” in the left tree then left clicking on “Reports” and choosing “Print/View Input Data”

 Weather Reports ΣΣ

---

Design

☐ Design Parameters and MSHGs

☐ Design Temperature Profiles

☐ Design Temperature Profile Graph For: July

☐ Design Solar Profiles For: July

---

Simulation

☐ Simulation Weather Data Summary

☒ Simulation Weather Profiles From: Aug. 23 To: Aug. 31

☐ Simulation Temperature Profile Graph From: Jan. 1 To: Dec. 31

☐ Simulation Solar Profile Graph From: Jan. 1 To: Jan. 1

Restore Defaults Print... Preview... Cancel Help

**ASK FOR SIMULATION  
WEATHER PROFILES  
FOR AUGUST 18-31<sup>ST</sup>.**

Monday, August 23

Hour	Dry-Bulb ( °F )	Wet-Bulb ( °F )	Beam Solar on Horiz. ( BTU/(hr·ft²) )	Total Solar on Horiz. ( BTU/(hr·ft²) )
0000	78.1	75.8	0.0	0.0
0100	77.5	75.4	0.0	0.0
0200	77.0	75.7	0.0	0.0
0300	76.8	75.4	0.0	0.0
0400	76.5	75.0	0.0	0.0
0500	77.0	74.4	0.0	0.0
0600	80.6	76.6	6.7	21.6
0700	83.7	78.0	33.6	78.9
0800	86.0	79.2	54.8	132.5
0900	89.6	77.6	94.1	191.4
1000	90.3	77.8	90.4	214.0
1100	89.6	77.7	97.0	232.0
1200	91.4	77.0	110.1	241.3
1300	91.0	76.7	124.4	238.5
1400	91.4	77.0	119.6	213.4
1500	89.6	76.5	85.1	161.5
1600	88.5	76.6	50.3	101.0
1700	86.0	76.8	14.1	36.6
1800	80.6	76.6	0.0	0.6
1900	80.2	76.4	0.0	0.0
2000	78.8	76.1	0.0	0.0
2100	78.8	76.1	0.0	0.0
2200	77.7	75.6	0.0	0.0
2300	77.0	75.7	0.0	0.0

Tuesday, August 24

Hour	Dry-Bulb ( °F )	Wet-Bulb ( °F )	Beam Solar on Horiz. ( BTU/(hr·ft²) )	Total Solar on Horiz. ( BTU/(hr·ft²) )
0000	77.0	75.7	0.0	0.0
0100	76.6	75.2	0.0	0.0
0200	77.0	75.7	0.0	0.0
0300	77.0	74.4	0.0	0.0



## Workshop 2 – Editing Schedules

This workshop focuses on editing the previously created schedules from our system design load calculations and were included in the retrieved archive. **Please add the following profiles to the schedule as noted:**



### **Lights Classroom Schedule**

#### **Add Profile #4 – Energy Weekday**

Hours     00-06: 05%  
              07: 25%  
              08-11: 90%  
              12: 05%  
              13-15: 90%  
              16: 40%  
              17-23: 05%

#### **Add Profile #5 – Energy Weekend**

Hours     00-23: 05%

On the Assignments tab, assign **Profile #4** to **Monday thru Friday** in all months **except June and July**. Assign existing **Profile #2** from the design load phase to **Monday thru Friday in the month of June only**. Assign existing **Profile #3** to **Monday thru Holiday** for the month of **July** only.

Assign **Profile #5** to day types **Saturday, Sunday, and Holiday** for all months **except July**. Refer to Figure 2.1 for additional details.

Figure 2.1 - Schedule - Profile Assignments-Lights Classrooms

Schedule Properties - [Lights - Classrooms]

Schedule Type | Hourly Profiles | **Assignments**

Click and Drag

	J	F	M	A	M	J	J	A	S	O	N	D
Design	1	1	1	1	1	2	1	1	1	1	1	1
Mon.	4	4	4	4	4	2	3	4	4	4	4	4
Tue.	4	4	4	4	4	2	3	4	4	4	4	4
Wed.	4	4	4	4	4	2	3	4	4	4	4	4
Thu.	4	4	4	4	4	2	3	4	4	4	4	4
Fri.	4	4	4	4	4	2	3	4	4	4	4	4
Sat.	5	5	5	5	5	5	3	5	5	5	5	5
Sun.	5	5	5	5	5	5	3	5	5	5	5	5
Holiday	5	5	5	5	5	5	3	5	5	5	5	5

Click Here

3: Summer or Press 3

1: Design Day 2: Summer School

4: Energy

5: Energy

6: Profile Six

7: Profile Seven

8: Profile Eight

Use the mouse or the arrow keys to select a block of cells and press a number key or click a profile to assign it to those days/months.

Click OK when finished

OK Cancel Help

## **People Classroom Schedule THIS ONE IS DONE ALREADY IN THE ARCHIVE**

### **Add Profile #4 – Energy Weekday**

Hours 00-06: 00%  
Hour 07: 10%  
Hours 08-11: 90%  
Hour 12: 10%  
Hours 13-15: 90%  
Hour 16: 25%  
Hour 17: 10%  
Hours 18-23: 00%

### **Add Profile #5 – Energy Saturday**

Hours 00-07: 00%  
Hours 08-12: 10%  
Hours 13-23: 00%

On the Assignments tab, assign **Profile #4** to day types **Monday thru Friday** in **all months except June and July**. Assign **Profile #2** to day types **Monday through Friday** for **June** only and **Profile #3** to **Monday thru Holiday** in **July** only *plus* **Sunday and Holiday** for all twelve (12) months.

Assign **Profile #5** to day type **Saturday** for all months **except July**. Refer to Figure 2.2 for details.

Figure 2.2 - Schedule–Profile Assignments–People–Classrooms



**Schedule Properties - [People - Classrooms]**

Schedule Type | Hourly Profiles | **Assignments**

Months: J F M A M J J A S O N D

Design	1	1	1	1	1	2	3	1	1	1	1	1
Mon.	4	4	4	4	4	2	3	4	4	4	4	4
Tue.	4	4	4	4	4	2	3	4	4	4	4	4
Wed.	4	4	4	4	4	2	3	4	4	4	4	4
Thu.	4	4	4	4	4	2	3	4	4	4	4	4
Fri.	4	4	4	4	4	2	3	4	4	4	4	4
Sa.	5	5	5	5	5	3	5	5	5	5	5	5
Sun.	3	3	3	3	3	3	3	3	3	3	3	3
Holiday	3	3	3	3	3	3	3	3	3	3	3	3

Click and Drag

Click Here or Press 3

1: Design Day 2: Summer School

3: Summer 4: Weekday

5: Saturday 6: Profile Six

7: Profile Seven 8: Profile Eight

Use the mouse or the arrow keys to select a block of cells and press a number key or click a profile to assign it to those days/months.

Click OK when finished

OK Cancel Help

The remaining schedules were completed and included in the retrieved archive. They are shown below for reference only.

## Schedule Profile Assignments Input Details

### Lights - Classrooms (Fractional)

#### Hourly Profiles:

##### 1: Design Day

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	10	10	10	10	10	10	10	10	100	100	100	100	100	100	100	100	30	10	10	10	10	10	10	10

##### 2: Summer School

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	5	5	5	5	5	5	5	5	60	60	60	60	60	25	5	5	5	5	5	5	5	5	5	5

##### 3: Summer Shutdown

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5

##### 4: Energy Weekdays

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	5	5	5	5	5	5	5	5	90	90	90	90	5	90	90	90	40	5	5	5	5	5	5	5

## 5:Energy Weekends

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5

## Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	2	3	1	1	1	1	1
Monday	4	4	4	4	4	2	3	4	4	4	4	4
Tuesday	4	4	4	4	4	2	3	4	4	4	4	4
Wednesday	4	4	4	4	4	2	3	4	4	4	4	4
Thursday	4	4	4	4	4	2	3	4	4	4	4	4
Friday	4	4	4	4	4	2	3	4	4	4	4	4
Saturday	5	5	5	5	5	5	3	5	5	5	5	5
Sunday	5	5	5	5	5	5	3	5	5	5	5	5
Holiday	5	5	5	5	5	5	3	5	5	5	5	5

## [ENERGY SIMULATION]

### People - Classrooms (Fractional)

#### Hourly Profiles:

##### 1: Design Day

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	5	100	100	100	100	100	100	100	100	40	10	0	0	0	0	0	0

##### 2: Summer School

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	0	40	40	40	40	40	10	0	0	0	0	0	0	0	0	0	0

##### 3: Summer Shutdown

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

##### 4: Weekday Energy

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	10	90	90	90	90	10	90	90	90	25	10	0	0	0	0	0	0

##### 5: Energy Saturday

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	0	10	10	10	10	10	0	0	0	0	0	0	0	0	0	0	0

#### Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	2	3	1	1	1	1	1
Monday	4	4	4	4	4	2	3	4	4	4	4	4
Tuesday	4	4	4	4	4	2	3	4	4	4	4	4
Wednesday	4	4	4	4	4	2	3	4	4	4	4	4
Thursday	4	4	4	4	4	2	3	4	4	4	4	4
Friday	4	4	4	4	4	2	3	4	4	4	4	4
Saturday	5	5	5	5	5	5	3	5	5	5	5	5
Sunday	3	3	3	3	3	3	3	3	3	3	3	3
Holiday	3	3	3	3	3	3	3	3	3	3	3	3



People - Corridors (Fractional)

Hourly Profiles:

1: Design Day

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	50	100	100	100	100	100	100	100	100	30	10	0	0	0	0	0	0

2: Summer School

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0																		0	0	0	0	0	0

3: Summer Shut

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0																		0	0	0	0	0	0

4: Weekday Ener

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0																		0	0	0	0	0	0

5: Energy Weekends

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

ALL THE SCHEDULES SHOWN HERE ARE ALREADY COMPLETED IN YOUR ARCHIVE. I PRINTED THE INPUTS AS SHOWN ON THESE FOLLOWING PAGES.

Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	2	3	1	1	1	1	1
Monday	4	4	4	4	4	2	3	4	4	4	4	4
Tuesday	4	4	4	4	4	2	3	4	4	4	4	4
Wednesday	4	4	4	4	4	2	3	4	4	4	4	4
Thursday	4	4	4	4	4	2	3	4	4	4	4	4
Friday	4	4	4	4	4	2	3	4	4	4	4	4
Saturday	5	5	5	5	5	5	3	5	5	5	5	5
Sunday	5	5	5	5	5	5	3	5	5	5	5	5
Holiday	5	5	5	5	5	5	3	5	5	5	5	5

## [ENERGY SIMULATION]

### People IT Room (Fractional)

#### Hourly Profiles:

##### 1:Design Day

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	10	100	0	0	0	100	0	0	100	0	10	0	0	0	0	0	0

##### 2:Summer School

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	0	0	40	0	0	40	0	0	0	0	0	0	0	0	0	0	0

##### 3:Summer Shutdown

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

**ALL THE SCHEDULES SHOWN HERE ARE ALREADY COMPLETED IN YOUR ARCHIVE. I PRINTED THE INPUTS AS SHOWN ON THESE FOLLOWING PAGES.**

#### Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	2	2	1	1	1	1	1
Monday	1	1	1	1	1	2	2	1	1	1	1	1
Tuesday	1	1	1	1	1	2	2	1	1	1	1	1
Wednesday	1	1	1	1	1	2	2	1	1	1	1	1
Thursday	1	1	1	1	1	2	2	1	1	1	1	1
Friday	1	1	1	1	1	2	2	1	1	1	1	1
Saturday	3	3	3	3	3	3	3	3	3	3	3	3
Sunday	3	3	3	3	3	3	3	3	3	3	3	3
Holiday	3	3	3	3	3	3	3	3	3	3	3	3

### Equipment IT (Fractional)

#### Hourly Profiles:

##### 1:design

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	25	25	25	25	25	25	25	80	80	50	50	50	80	70	60	50	80	50	25	25	25	25	25	25

##### 2:Summer

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25

#### Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	2	2	1	1	1	1	1
Monday	1	1	1	1	1	2	2	1	1	1	1	1
Tuesday	1	1	1	1	1	2	2	1	1	1	1	1
Wednesday	1	1	1	1	1	2	2	1	1	1	1	1
Thursday	1	1	1	1	1	2	2	1	1	1	1	1
Friday	1	1	1	1	1	2	2	1	1	1	1	1
Saturday	2	2	2	2	2	2	2	2	2	2	2	2
Sunday	2	2	2	2	2	2	2	2	2	2	2	2
Holiday	2	2	2	2	2	2	2	2	2	2	2	2

## [ENERGY SIMULATION]

### Occupied Schedule - Classroom (Fan / Thermostat)

#### Hourly Profiles:

##### 1: Design Day

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	U	U	U	U	U	U	O	O	O	O	O	O	O	O	O	O	O	O	U	U	U	U	U	U

##### 2: Summer School

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	U	U	U	U	U	U	O	O	O	O	O	O	O	O	U	U	U	U	U	U	U	U	U	U

##### 3: Summer Shutdn Week

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	U	U	U	U	U	U	O	O	O	O	O	O	O	O	O	O	O	O	U	U	U	U	U	U

##### 4: Energy Weekdays

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	U	U	U	U	U	U	O	O	O	O	O	O	O	O	O	O	O	O	U	U	U	U	U	U

O = Occupied; U = Unoccupied

#### Assignments:


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	2	3	1	1	1	1	1
Monday	4	4	4	4	4	2	3	4	4	4	4	4
Tuesday	4	4	4	4	4	2	3	4	4	4	4	4
Wednesday	4	4	4	4	4	2	3	4	4	4	4	4
Thursday	4	4	4	4	4	2	3	4	4	4	4	4
Friday	4	4	4	4	4	2	3	4	4	4	4	4
Saturday	3	3	3	3	3	3	3	3	3	3	3	3
Sunday	3	3	3	3	3	3	3	3	3	3	3	3
Holiday	3	3	3	3	3	3	3	3	3	3	3	3

**ALL THE SCHEDULES SHOWN HERE ARE ALREADY COMPLETED IN YOUR ARCHIVE. I PRINTED THE INPUTS AS SHOWN ON THESE FOLLOWING PAGES.**



Blank Page

# Workshop 3 Inputs



Blank Page






## Workshop 3 - Modeling 4-Pipe Fan Coil Unit Air Systems - Using the Equipment Wizard.

Launch the Equipment Wizard by selecting the Wizard item on the Menu bar and clicking the Equipment Wizard on the list. See Figure 3.1 for details.

Figure 3.1 - Launching the Equipment Wizard



Next add the following spaces top the system. Assign spaces D100 through D114 to the building and click OK. Refer to Figure 3.2 for additional details.

Figure






Figure 3.8 - Rerun and View all Air System Simulation Results

Reports	Table	Graph	TXT	Time Specifications
Monthly Simulation Results	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	For <input type="text" value="August"/> From <input type="text" value="Aug. 25"/> to <input type="text" value="Aug. 25"/>
Daily Simulation Results	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Hourly Simulation Results	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Unmet Loads Report	<input type="checkbox"/>			
Zone Temperature Report	<input checked="" type="checkbox"/>			

Graph Specifications

☒ Precool Coil Load (kBTU)  
☒ **Terminal Cooling Coil Load (kBTU)**  
☐ Ventilation Fan (kWh)  
☐ Exhaust Fan (kWh)  
☐ Terminal Fan (kWh)  
☐ Vent. Reclaim Device (kWh)  
☐ Lighting (kWh)

Select up to 3 data items for the graph. All must have the same units of measure.

Note: Graph options are only available when a single system has been selected and that system was previously simulated.

**LETS EXAMINE SIMULATION  
REPORTS REFLECTING  
OUR LOCATION**



## System Simulation Reports Monthly, Daily and Hourly Simulation Results

### Monthly Air System Simulation Results



Monthly Simulation Results for ALT1 - Whole Building	
Project Name: TRINIDAD ENERGY UNSOLVED ARCHIVE 1 WK THRU	10/19/2013
Prepared by: camer corporation	07:23AM


Air System Simulation Results (Table 1) :

Month	Precool Coil Load (kBTU)	Terminal Cooling Coil Load (kBTU)	Ventilation Fan (kWh)	Exhaust Fan (kWh)	Terminal Fan (kWh)	Vent. Reclaim Device (kWh)	Lighting (kWh)
January	4866	141110	227	151	578	47	16641
February	4875	129863	227	151	547	46	15283
March	6036	157599	261	174	616	55	16997
April	6327	152996	238	159	589	50	16249
May	10873	167656	238	159	606	50	16818
June	3709	64740	159	106	338	34	5849
July	0	24926	0	0	64	0	611
August	8701	163062	238	159	603	50	16643
September	8297	159810	238	159	595	50	16249
October	7048	157940	238	159	607	50	16818
November	8963	158677	250	166	599	53	16426
December	6215	149672	261	174	604	55	16822
Total	75909	1628050	2574	1716	6346	541	171404

Air System Simulation Results (Table 2) :

Month	Electric Equipment (kWh)
January	3227
February	2931
March	3252
April	3137
May	3235
June	1454
July	506
August	3235
September	3137
October	3235

## Monthly Air System Simulation Graph



## Daily Air System Simulation Results

Daily Air System Simulation Results for August (Table 1):


Daily Simulation Results for ALT1 - Whole Building							
Project Name: TRINIDAD ENERGY UNSOLVED ARCHIVE 1 WK THRU						10/19/2013	
Prepared by: Carrier Corporation						07:23AM	

Daily Air System Simulation Results for August (Table 1):

Day	Precool Coil Load (kBtu/h)	Terminal Cooling Coil Load (kBtu/h)	Ventilation Fan (kW/h)	Exhaust Fan (kW/h)	Terminal Fan (kW/h)	Vent. Reclaim Device (kW/h)	Lighting (kW/h)
1	0	2555	0	0	8	0	39.4
2	395	5903	11	8	22	2	57.1
3	431	5865	11	8	23	2	57.1
4	359	5921	11	8	23	2	57.1
5	393	5942	11	8	23	2	57.1
6	405	5957	11	8	23	2	57.1
7	0	4779	0	0	15	0	57.0
8	0	3366	0	0	11	0	39.4
9	417	5995	11	8	23	2	57.1
10	443	5995	11	8	23	2	57.1
11	353	5950	11	8	23	2	57.1
12	360	5862	11	8	23	2	57.1
13	370	5907	11	8	23	2	57.1
14	0	4800	0	0	15	0	57.0
15	0	3205	0	0	11	0	39.4
16	415	6037	11	8	23	2	57.1
17	434	6012	11	8	23	2	57.1
18	404	5974	11	8	23	2	57.1
19	395	5909	11	8	23	2	57.1
20	299	5745	11	8	23	2	57.1
21	0	4779	0	0	15	0	57.0
22	0	3227	0	0	11	0	39.4
23	359	5863	11	8	23	2	57.1
24	514	6053	11	8	23	2	57.1
25	473	6055	11	8	23	2	57.1
26	505	6032	11	8	23	2	57.1
27	455	6065	11	8	23	2	57.1
28	0	4901	0	0	15	0	57.0
29	0	3318	0	0	11	0	39.4
30	453	6120	11	8	23	2	57.1
31	0	2905	0	0	9	0	39.4
Total	8701	163062	238	159	600	50	16543



## Daily Air System Simulation Results



## Hourly Air System Simulation Results


Hourly Simulation Results for ALT1 - Whole Building	
Project Name: TRINIDAD ENERGY UNSOLVED ARCHIVE 1 WK THRU	10/19/2013
Prepared by: carrier corporation	07:23AM

Table 1.1 Hourly Air System Simulation Results for Wednesday, August 25

Hour	Precool Coil Load (MBH)	Terminal Cooling Coil Load (MBH)	Ventilation Fan (kW)	Exhaust Fan (kW)	Terminal Fan (kW)	Vent. Reclaim Device (kW)	Lighting (kW)
0000	0.0	157.9	0.0	0.0	0.5	0.0	23.7
0100	0.0	161.0	0.0	0.0	0.5	0.0	23.7
0200	0.0	163.4	0.0	0.0	0.5	0.0	23.7
0300	0.0	166.7	0.0	0.0	0.5	0.0	23.7
0400	0.0	168.4	0.0	0.0	0.5	0.0	23.7
0500	0.0	170.3	0.0	0.0	0.5	0.0	23.7
0600	18.7	327.0	0.9	0.6	1.4	0.2	23.7
0700	18.1	337.2	0.9	0.6	1.4	0.2	23.8
0800	21.6	344.3	0.9	0.6	1.4	0.2	24.0
0900	38.5	355.8	0.9	0.6	1.4	0.2	23.8
1000	42.0	355.4	0.9	0.6	1.4	0.2	23.8
1100	50.4	357.9	0.9	0.6	1.4	0.2	23.8
1200	63.7	366.1	0.9	0.6	1.4	0.2	24.0
1300	50.6	359.6	0.9	0.6	1.4	0.2	23.8
1400	54.2	356.4	0.9	0.6	1.4	0.2	23.8
1500	31.8	346.3	0.9	0.6	1.4	0.2	23.8
1600	50.1	356.3	0.9	0.6	1.4	0.2	23.8
1700	33.5	346.0	0.9	0.6	1.4	0.2	23.8
1800	0.0	129.3	0.0	0.0	0.4	0.0	23.7
1900	0.0	137.5	0.0	0.0	0.4	0.0	23.7
2000	0.0	142.5	0.0	0.0	0.4	0.0	23.7
2100	0.0	145.2	0.0	0.0	0.4	0.0	23.7
2200	0.0	153.1	0.0	0.0	0.5	0.0	23.7
2300	0.0	151.2	0.0	0.0	0.5	0.0	23.7
Total	473.2	6057.8	11.3	7.6	23.0	2.4	571.3

## Hourly Air System Simulation Results Graph

Hourly Simulation Results for Wednesday, August 25 (day 237) thru Wednesday, August 25 (day 237)



## Zone Temperature Report

### 1. Zone Temperature Statistics

Zone Temperature Report for AL T1 - Whole Building													
Project Name: TRINIDAD ENERGY UNOLVED ARCHIVE 1 WK THRU													
Prepared by: carter corporation													
10/19/2013 07:56AM													

#### 1. Zone Temperature Statistics

Zone Name	Occ Max Zone Temp (°F)	Occ Hours More Than 5.0 °F Above Throt. Range	Occ Hours 1.0 to 5.0 °F Above Throt. Range	Occ Cooling Setpoint plus Throt. Range (°F)	Occ Hours Within Throt. Range or Dead- band	Occ Heating Setpoint minus Throt. Range (°F)	Occ Hours 1.0 to 5.0 °F Below Throt. Range	Occ Hours More Than 5.0 °F Below Throt. Range	Occ Min Zone Temp (°F)	Unocc Max Zone Temp (°F)	Unocc Cooling Setpoint plus Throt. Range (°F)	Unocc Heating Setpoint minus Throt. Range (°F)	Unocc Min Zone Temp (°F)
D100 - IT Room	74.1	0	0	73.5	2724	68.5	0	0	71.9	82.3	83.5	63.5	82.2
D101 - Classroom	76.5	0	2417	73.5	307	68.5	0	0	72.5	82.9	83.5	63.5	78.1
D102 - Classroom	76.5	0	2417	73.5	307	68.5	0	0	72.5	82.9	83.5	63.5	78.1
D103 - Classroom	76.5	0	2417	73.5	307	68.5	0	0	72.5	82.9	83.5	63.5	78.1
D104 - Classroom	75.8	0	1503	73.5	1221	68.5	0	0	72.5	82.8	83.5	63.5	79.5
D105 - South Vestibule	73.8	0	0	73.5	2724	68.5	0	0	72.4	82.4	83.5	63.5	77.3
D106 - Classroom	75.9	0	1158	73.5	1586	68.5	0	0	72.5	82.8	83.5	63.5	78.2
D107 - Classroom	76.2	0	2119	73.5	605	68.5	0	0	72.5	82.8	83.5	63.5	78.0
D108 - Music Room	77.6	0	2556	73.5	168	68.5	0	0	72.3	82.9	83.5	63.5	76.9
D109 - Music Practice	75.7	0	152	73.5	2672	68.5	0	0	72.4	82.8	83.5	63.5	77.6
D110 - Music Files	76.8	0	1385	73.5	1339	68.5	0	0	72.5	82.7	83.5	63.5	76.5
D111 - Music Office	74.8	0	1	73.5	2723	68.5	0	0	72.6	82.7	83.5	63.5	79.4
D112 - West Vestibule	73.7	0	0	73.5	2724	68.5	0	0	72.5	82.4	83.5	63.5	77.3
D113 - Corridor	78.6	13	2591	73.5	120	68.5	0	0	72.7	82.6	83.5	63.5	75.0
D114 - Corridor	78.8	46	2576	73.5	102	68.5	0	0	72.7	82.7	83.5	63.5	74.9

Note: For any occupied hours in which cooling is unavailable or scheduled off, zone temperature out of range statistics are not reported.  
Note: For any occupied hours in which heating is unavailable or scheduled off, zone temperature out of range statistics are not reported.

Note: For any occupied hours in which cooling is unavailable or scheduled off, zone temperature out of range statistics are not reported.





# Workshop 4 Inputs



Blank Page



## Workshop 4 Modeling Chillers, Towers, (Boilers), and Hydronic Plants



This workshop consists of entering primarily cooling plant information including detailed performance on chillers, towers, (we will also cover boilers) and the distribution piping and pumping.

There are several ways to enter the data into HAP. One option is using the Equipment Wizard found in HAP. Utilizing this wizard creates not only the Air Systems but also the hydronic plants that connect to the air systems. When we used the Equipment Wizard to create the 2Pipe FCU air system in workshop 3 the wizard automatically created the Chiller plant for the air system's source of cooling and heating. Refer to Figures 3.3b and c for additional details. The wizard created plants use the "auto-size" feature when creating the chillers.



We will now create specific chillers, and towers (and boilers) for our design alternatives.



The first step in this workshop is retrieving the second class archive which contains all air systems for our design alternatives.

In the previous workshop #3, we used the Equipment Wizard to Highlight and retrieve HAP v4.6 for **Energy Simulation Archive 2 Unsolved** into the existing project and then save the project.

**In this workshop we create several chillers, and a cooling tower. We will not create boiler plants as would be done in most areas of the USA, we will just use electric heat in our air systems for Trinidad.**

**HAP considers all the air systems assigned to the plant in determining the peak coincident, or "block" cooling load**, taking into account diversity on several levels. Diversity is defined as the block load divided by the sum of the individual peak loads.

HAP considers diversity between the zones within an air system and between systems when a plant serves multiple air systems. The plant design load calculation analyses the total plant load (sum of air system loads) for each hour and finds the largest load. This analysis includes the zone and air system diversity. When using air system multipliers for identical air systems, the resulting plant sizing includes those requirements in determining the peak plant load.

HAP calculates the total building, project or campus block (cooling) load accounting for diversity in sizing the plant and plant equipment.


**We begin the process by determining the chiller plant sizing** for the A Base Case and also the C Alt #2 design Case. In the HAP main window, click on the Plant item in the tree and select "create new plant" in the detail pane. Refer to Figure 4.2 for details.

Figure 4.2 - Create New Chiller Plant



This opens the Plant Input form for data entry. Please refer to Figure 4.3 for A Base Case Chilled Water Plant sizing procedure.


Figure 4.3 - Generic Chiller Plant Sizing Details



Next click on the "Systems" tab and add the A Base Case air systems to the chilled water plant and left click on the OK button. Refer to Figure 4.4 for details.

Figure 4.4 - Add "A Base Case" Air Systems to the Generic Chilled Water Plant





This takes us back to the HAP plant screen showing the newly created plant on the list. Highlight the plant and use the right mouse click then select "print/view design results" from the selection list. Refer to Figures 4.5 and 4.6 for additional details.

Figure 4.5 - Calculate Chiller Plant Design Load







Figure 4.6 - Select Print/View Design Results – Cooling Plant Sizing Summary



Review the follow details for the plant sizing.

Plant Sizing Summary for A SIZING		
TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 wk thru carrier		07/24/2017 08:58PM

#### 1. Plant Information:

Plant Name ..... A SIZING  
 Plant Type ..... Generic Chilled Water  
 Design Weather ..... Port of Spain, Trinidad & Tobago

#### 2. Cooling Plant Sizing Data:

Maximum Plant Load ..... 267.6 Tons  
 Load occurs at ..... Sep 1500  
 ft<sup>2</sup>/Ton ..... 222.6 ft<sup>2</sup>/Ton  
 Floor area served by plant ..... 59553.0 ft<sup>2</sup>

#### 3. Coincident Cooling Loads for Sep 1500

Air System Name	Mult.	System Cooling Coil Load [Tons]
A01 - AHU A1 - Commons/Offices	1	45.6
A02 - AHU A2 - Classroom/Misc.	1	40.3
A03 - AHU B1 - Classrooms	1	44.5
A04 - Project 1 Gymnasium	1	42.6
A05 - AHU C2 - Aerobics Gym	1	15.1
A06 - AHU C3 - Locker Rooms	1	30.2
A07 - AHU C4 - Office/Classroom	1	11.9
A09 - Project 2 - Wing D PFPMXB	1	18.4
A10 - AHU D2 - Classrooms	1	19.1

Air system loads are for coils whose cooling source is 'Chilled Water' or 'Any'.

System loads are for coils whose cooling source is 'Chilled Water' or 'Any'.

Figure 4.7 details the chiller plant sizing summary for the A Base Design Case air systems.

The resulting peak plant load for the "A Base Case" is 268 tons. This peak load includes diversity as discussed above. **For our "A Base Case" design we decide to use two (2) equally sized air-cooled chillers in our chiller plant.** With the maximum plant load determined, we can select specific chillers for the chiller plant. This is accomplished in one of several ways. For our exercise we selected the chillers in the e-Cat Chiller Builder program. After finalizing the selection, we exported the chiller data for use in our project. This allows us to import the actual chiller performance for a detailed energy analysis of the chiller plant. Copies of the chiller data files are on the accompanying flash drive.



## Air Cooled Chiller Selection

Design based on the following parameters.

Quantity: 2 Air-Cooled Packaged Rotary Screw Chillers  
Capacity: 140 Tons each at 95° F plus a safety factor of 15%  
LCHWT: 44° F  
ECHWT: 56° F

Figure 4.8 - Details of Chiller Selection using e-Cat Selection Software.

Run the calculations and generate the Chiller Performance Report.

See following page for details.

## AquaForce™ Air-Cooled Screw Chiller



### Unit Information

Tag Name: B Alt 1 A/C Chillers  
 Model Number: 30XA140  
 Quantity: 1  
 Manufacturing Source: Charlotte, NC USA  
 Refrigerant: R134A  
 Independent Refrigerant Circuits: 2  
 Shipping Weight: 10497 lb  
 Operating Weight: 10629 lb  
 Unit Length: 236 in  
 Unit Width: 89 in  
 Unit Height: 90 in

### Evaporator Information

Fluid Type: Fresh Water  
 Fouling Factor: 0.00010 (hr-sqft-F)/BTU  
 Number of Passes: 2  
 Leaving Temperature: 44.0 °F  
 Entering Temperature: 54.0 °F  
 Fluid Flow: 318.7 gpm  
 Pressure Drop: 13.3 ft

### Condenser Information

Altitude: 564 ft  
 Number of Fans: 10  
 Total Condenser Fan Air Flow: 93000 CFM  
 Entering Air Temperature: 95.0 °F

### Integrated Pump Information

No Pump Selected

### Performance Information

Cooling Capacity: 133.3 Tons  
 Total Compressor Power: 133.7 kW  
 Total Fan Motor Power: 12.9 kW  
 Total Unit Power (without pump): 146.6 kW  
 Efficiency (without pump): 10.91 EER  
 A-Weighted Sound Power Level: 101 dbA

### Accessories and Installed Options

Freeze Protection  
 Micro Channel  
 XL Starter  
 Single Point  
 No Coil Trim Panels  
 Touch Pilot Display

### Electrical Information

Unit Voltage: 460-3-60 V-Ph-Hz  
 Connection Type: Single Point  
 Minimum Voltage: 414 Volts  
 Maximum Voltage: 506 Volts

Amps	Electrical Circuit 1	Electrical Circuit 2
MCA	267.3	---
MOCP	400.0	---
ICF	1030.4	---



WE MADE A SELECTION IN THE  
CARRIER CHILLER BUILDER FOR A 140  
TON CHILLER. IT IS IN THE "3. CHILLERS  
FOR IMPORT" FOLDER ON YOUR  
DESKTOP

### Entering Chiller Performance Data

**There are three (3) methods to enter chiller data into HAP.**

1. Import Chiller
2. Chiller Template
3. User Defined Chiller Type

**In this Workshop, we enter chiller data using method 1 and method 2. We will demonstrate method 3 but not use it in a workshop.**



For our Air Cooled Packaged Screw Chiller we selected using the Packaged Chiller Builder program, we have included in your flashdrive a file that contains the detailed chiller performance for use by HAP. To import the actual performance matrix of our chiller for use in our plant model we use the "Import Chiller" method in the chiller properties input form. Refer to Figure 4.9a through Figure 4.9d for details.



We placed the Chiller Export Archive file on the accompanying Flash Drive. To Import this chiller for this exercise open the chiller properties form and Double Click on the "New Default Chiller" in the chiller Library, then click on the Import Chiller button as detailed in Figure 4.9a.

Figure 4.9a - Chiller Input Form – Import Chiller Data

**Navigate to your desktop go to the chiller tab** and select the " 30 XA 140" Click the OPEN button to import the chiller into HAP.

Figure 4.9b – Chiller Properties General Tab – Imported Chiller Data

The screenshot shows the 'Chiller Properties - [Chiller1]' dialog box with the 'General' tab selected. The 'Chiller Name' field contains 'Chiller1'. The 'Chiller Type' dropdown menu is set to 'A/C Packaged Screw'. The 'Notes' text area contains the text 'Data generated by Carrier Electronic Catalog Selection Program'. The 'Data Source' dropdown menu is set to 'Imported Data'. There are buttons for 'Chiller Template...', 'Import Chiller...', 'OK', 'Cancel', and 'Help'. A status bar at the bottom left says 'Click Ok to accept changes'.

Note: The Chiller properties are imported from the archived file and include all selection design inputs and calculated performances for IPLV and NPLV using the full operating matrix of the chiller.

**We should rename the default Chiller1 name to something that makes more sense i.e. "A Base Case AC Chillers" or similar.**



Figure 4.9c - Chiller Properties Design Inputs – Imported Chiller Data

The screenshot shows a software window titled "Chiller Properties - [AA BASE AIR COOLED]". It has four tabs: "General", "Design Inputs" (which is selected), "Cooling Performance", and "Heating Performance".

Under the "Design Inputs" tab, the following fields are visible:


- Name:** A text box containing "AA BASE AIR COOLED". To its right is a button labeled "Chiller Template...".
- Equipment Function:** A dropdown menu showing "Chiller (Chilled Water Only)". To its right is a button labeled "Import...".
- Equipment Type:** A dropdown menu showing "A/C Packaged Screw".
- Notes:** A text area containing the text "Data generated by Carrier Electronic Catalog Selection Program." with up and down arrow icons on the right side.
- Data Source:** A text box containing "Imported Data".

At the bottom right of the dialog are three buttons: "OK", "Cancel", and "Help".

Below the dialog box, there is a status bar with the text "Name" on the left and "Max. Characters: 35" on the right.

Note: All data is part of the import file.

Figure 4.9d – Chiller Properties Performance Map – Imported Chiller Data



Next, let's run the plant block load on the "C" air systems.

Use the following information for modeling the water-cooled screw chiller for the C Alt 2 design.

**Now calculate the design load for the "C" Alt-2 chiller plant.**

**Note:** The calculated load for C Alt 2 is **213.2** TONS.



Figure 4.10 – Non-Integrated Part Load Value C Alt 3 Water-cooled screw

Figure 4.10 – Non-Integrated Part Load Value  
Integrated Part Load Value (ARI)

IPLV:..... **0.537 kW/Ton 222.5 TONS**

Unit Performance	100	75	50	25
Percent Full Load Cooling Capacity, %	100	75	50	25
Percent of Full Load Power, %	100.0	61.6	36.9	29.1
Unloading Sequence	Default	Default	Default	Default
Cooling Capacity, Tons	222.5	166.9	111.3	55.6
Total Unit Power, kW	147.7	91.0	54.4	43.0
Efficiency, EER	18.08	22.02	24.52	15.51
Efficiency, kW/Ton	<b>0.664</b>	<b>0.545</b>	<b>0.489</b>	<b>0.774</b>

Evaporator Data	
Fluid Entering Temp	
Fluid Leaving Temp	
Fluid Flow Rate, gpm	
Fouling Factor, (hr·ft <sup>2</sup> ·°F/Btu)	

Condenser Data	
Fluid Entering Temp	
Fluid Leaving Temp	
Fluid Flow Rate, gpm	
Fouling Factor, (hr·ft <sup>2</sup> ·°F/Btu)	

**THIS IS A SCREW CHILLER SELECTION FOR USE WITH THE "C" AIR SYSTEMS. NOTICE WE HAVE THE QUARTER POINT DATA (PLV). THIS DATA CAN REFLECT ANY BRAND OR TYPE OF WATER-COOLED CHILLER YOU WANT TO MODEL.**

Double click "New Default Chiller" and we will enter the chiller for the "C" air systems into HAP using method #2, the "Template" method which uses a quarter point PLV approach. Enter the IPLV data from Figure 4.10 as detailed in Figures 4.11a through 4.11e.

Figure 4.11a – Define Chiller Part Load Performance Method #2 "Template" method.

Figure 4.11b – Chiller Template Design Inputs

Figure 4.11b – Chiller Template Design Inputs

Chiller Template: **W/C Packaged Screw**

Full Load LCHWT: 44.0 °F

Full Load ECWT: 85.0 °F

Full Load Capacity: 222.3 Tons

Full Load Power: 0.664 kW/Ton

Min ECWT Setpoint: 65.0 °F

Minimum Load: 15.0 %

Number of Part-Load Data Points: 4

% Load	ECWT	kW/Ton
100	85.0	0.664
75	75.0	0.575
50	65.0	0.489
25	65.0	0.774

**CONFIGURE 664/.545/.489/.774 KW/TON**

1. Select W/C Packaged Screw from Chiller Template dropdown  
 2. Enter Full Load and Minimum Load data  
 3. Enter the IPLV Part Load Performance data  
 4. Click OK after entering all chiller data into chiller template

Chiller input power for given part-load and temp Min: 0 100 kW/Ton Max: 5 000 kW/Ton

Figure 4.11c - Chiller Properties General Tab Template Data



Chiller Properties - [C Alt 2 WC Packaged Screw Chiller]

**General** | Design Inputs | Performance Map

Chiller Name: C Alt 2 WC Packaged Screw Chiller | Chiller Template...

Chiller Type: W/C Packaged Screw | Import Chiller...

Notes: Performance data was generated using the Chiller Template option.

Data Source: Template Data

Figure 4.11d - Chiller Properties Design Inputs Tab

Chiller Properties - [C Alt 2 W/C Chiller]

**Design Inputs**

**Fluid Temperatures**

Full Load LCHWT: 44.0 °F

Full Load ECWT: 85.0 °F

**Flow Rate(s)**

Cooler Flow Rate: 533.5 gpm

Condenser Flow Rate: 666.9 gpm

**Capacity**

☐ Auto-Size Capacity

Full Load Capacity: 222.3 Tons

**Controls and Features**

Minimum ECWT Setpoint: 65.0 °F

Minimum Load: 15.0 %

☐ Hot Gas Bypass

**Input Power**

Full Load Power: 9.664 kW/Ton

**534 EVAP GPM 667.6 CONDENSER GPM**

Design Inputs came from Chiller Template input performed in previous step.

Figure 4.11e – Chiller Properties Performance Map Tab

Chiller Properties - [C Alt 2 W/C Chiller]

General Design Inputs **Performance Map**

Chiller Performance (kW/Ton)

ECWT	Max Cap	100%	75%	50%	25%
90.0	0.721	0.721	0.705	0.760	1.203
85.0	0.664	0.664	0.648	0.700	1.107
80.0	0.610	0.610	0.595	0.642	1.016
75.0	0.558	0.558	0.545	0.588	0.931
70.0	0.510	0.510	0.498	0.537	0.850
65.0	0.464	0.464	0.453	0.489	0.774

Chiller Capacity (Tons)

ECWT	Max Cap	100%	75%	50%	25%
90.0	222.3	222.3	166.7	111.2	55.6
85.0	222.3	222.3	166.7	111.2	55.6
80.0	222.3	222.3	166.7	111.2	55.6
75.0	222.3	222.3	166.7	111.2	55.6
70.0	222.3	222.3	166.7	111.2	55.6
65.0	222.3	222.3	166.7	111.2	55.6

Condenser Temp. Rows: 6

Part Load Columns: 5

Performance LCHWT Factors

a = -0.00300

b = 0.00000

Capacity LCHWT Factors

a = 0.00000

b = 0.00000

Chiller Performance and Chiller Capacity generated by the chiller template inputs

OK Cancel Help

Chiller Capacity for given part-load and temperature Min: 3.0 Tons Max: 5000.0 Tons

bove inputs are IPLV rating points based on 44/56 LCHWT/ECHWT, with adjusted Cooler and Condenser Water flow rates.

## Cooling Plant Sizing Summary Comparison Class Discussion

The maximum plant load for the water-cooled design case using air systems C1-C8 is **213.2 TONS**. Note that some of these air systems are fan coil units with DOAS (common vent).

For the air-cooled design case using air systems A01-A10, the plant load was **267.6 tons**. Some of these air systems are VAV. Both plants serve identical 59,553 ft<sup>2</sup> areas.

What contributes to the load difference between the plants? They have the same area, spaces, walls, roof, glass, and people.



We find the answer by comparing the Air System Design Load Summaries for the two plant types. (Not done as part of this workshop). The air-cooled chiller plant requires more ventilation air than the water-cooled chiller plant. But the primary reason for the tonnage difference is the FCU system using DOAS requires less total OA to comply with ASHRAE.

We selected the ASHRAE 62.1-2007 Ventilation sizing for all air systems in both plants. However, each VAV air system serves multiple zones requiring the use of the critical space equation for VAV systems in order to satisfy the critical zones requirements and comply with ASHRAE 62.1-2007. **The difference in the design cases results in a sizeable ventilation air load reduction.**



## Entering Cooling Tower Performance Data

Next, we need to verify the cooling tower performance for our water-cooled chiller. Before we do, there are several important terms definitions related to cooling towers including:


1. **Entering Wet Bulb** temperature is an important parameter in tower selection. For most areas in North America, an entering wet bulb temperature of 78°F is common. **For our exercise we will use 79F wet bulb**
2. **Approach** is the difference between the water leaving the tower and the entering wet bulb temperature of the air. A 6°F approach is what we will use for HVAC systems with a 79°F entering wet bulb and 85°F water leaving the tower. ( $85^{\circ}\text{F} - 79^{\circ}\text{F} = 6^{\circ}\text{F}$ )
3. **Range** is the difference in temperature of entering and leaving condenser water. An approximate 6°F range reflects approximately 3 gpm/ton flow rate in the condenser loop.

Check with your local cooling tower representative to confirm the design entering wet bulb and approach values for your area. The tower range must match the chiller condenser  $\Delta T$ .

1. Create a new cooling tower by opening the Cooling Tower Properties form.
2. Enter the cooling tower data found under the Chiller Properties Design Input Tab in Figure 4.11 D.
3. See details in Figure 4.12.



Figure 4.12 - Cooling Tower Properties for C Alt 2 WC Screw Chiller



**Cooling Tower Properties - [C TOWER]**

Name: C TOWER

668 CONDENSER GPM

Geo, Well, or Surface Water

Configuration

Water Flow Rate: 3.000 gpm/Ton

Configure the tower for 79 EWB, 10F range, 6F approach

Cooling Tower Model

Design Wet Bulb: 79.0 °F

Range at Design: 10.0 °F

Design Approach: 6.0 °F

Full Load Fan kW: 0.050 kW/Ton

Fan Control

Type of Control: Variable Speed Fan

Fan Electrical Efficiency: 94.0 %

% Airflow at Low Fan Speed: %

OK Cancel Help


Type of Minimum Setpoint Control



### Entering Boiler Performance Data

We are now ready to size our boiler plants and add boilers to our library. We start by sizing our A Base Case boiler load as detailed in the following Figures 4.13a through 4.13c. Create a new Generic Hot Water Plant and link all "A" design air systems.

Figure 4.13a Generic Hot Water Plant



**Plant Properties - [A Base Case Boiler Plant Sizing]**

General Systems

Plant Name: A Base Case Boiler Plant Sizing

Plant Type: Generic Hot Water Plant

WE WILL NOT CONFIGURE ANY BOILER PLANTS SO DISREGARD ALL BOILER INPUTS GOING FORWARD

## Workshop 5 Inputs



Blank Page



## Workshop 5 - Configuring “Final” Chiller and Boiler Plants



We created 2 chiller plants in our previous workshop, a chiller plant for our A Base Case and our C Alt 2 Design, as displayed in Figure 5.1.

Figure 5.1 – Chiller Plants Created in WS4.

Plant	Plant Type	Sizing Status	Simulation Status
<New default Plant>			
A Base Case Chiller Plant Sizing	Generic Chilled Water	Sized	
A Base Case Hot Water Boiler	Generic Hot Water	Sized	
C Alt 2 Chiller Plant Sizing	Generic Chilled Water	Sized	
C Alt 2 HW Boiler Plant Sizing	Generic Hot Water	Sized	

**NO BOILER PLANTS FOR OUR PROJECT FOR TRINIDAD TRAINING**

What is a Plant?

A Plant is the equipment and controls that provide cooling or heating to coils in one or more air systems. Examples include chiller plants, hot water or steam boiler plants and remote source chilled water, hot water or steam plants. This workshop consists of finalizing the two chiller plants in Workshop 4.

The base design case chiller plant consists of two Carrier 30XA 140 A/C (air-cooled) packaged screw chillers. The air systems served by this plant include all “A” designated air systems with chilled water coils. The configuration of the chiller plant is two chillers in sequence. The pumping and piping distribution system is a primary only with variable speed pumping and sized for a  $12^{\circ}\Delta T$  with 2% piping heat gain factor.

The “C Alt 2” chiller plant serves the “C” designated air systems. This plant consists of one 222.5 ton water-cooled screw chiller and a matching cooling tower. The pumping and piping distribution system is a primary only variable speed system sized for a  $12^{\circ}\Delta T$  and 2% piping heat gain factor.

**DOUBLE CLICK ON “A BASE” PLANT AND CHANGE FROM “GENERIC” TO “CHILLER PLANT”.**

Figure 5.2a – A Base Case Chiller Plant Data

Plant Properties - [A Base Case Chiller Plant Sizing]

**General** Systems

1. Change Plant Name to A Base Case 2-30XA A/C Screws  
2. From Plant Type dropdown, select “Chiller Plant”

Plant Name **1** A Base Case Chiller Plant Sizing

Plant Type Generic Chilled Water Plant **2**

Figure 5.2b – A Base Case Air Systems



Plant Properties - [A Base Case 2-30XA A/C Screws]

General **Systems** Configuration Schedule of Eqpt Distribution

Air Systems with Chilled Water Coils

A01 - AHU A1 - Commons/Offices	
A02 - AHU A2 - Classroom/Misc	
A03 - AHU B1 - Classrooms	
A04 - Project 1 - Gymnasium	
A05 - AHU C2 - Aerobic Gym	
A06 - AHU C3 - Locker Rooms	
A07 - AHU C4 - Office/Classroom	
A09 - Project 2 - Wing D PFPMXB	
A10 - AHU D2 - Classrooms	
B01 - AHU A1 - Commons/Office	
B02 - AHU A2 - Classrooms/Misc	
B03 - AHU B1 - Classrooms	
B04 - Project 1 Gymnasium	
B05 - AHU C2 - Aerobic Gym	
B06 - AHU C3 - Locker Rooms	
B07 - AHU C4 - Office/Classroom	
B09 - Project2- WingD PFPMXB	
B10 - AHU D2 - Classrooms	
C01 - 4PFCU D1 - Wing A(all)	

Add >>> Remove <<<

Plant Serves These Systems

A01 - AHU A1 - Commons/Offices	1
A02 - AHU A2 - Classroom/Misc	1
A03 - AHU B1 - Classrooms	1
A04 - Project 1 - Gymnasium	1
A05 - AHU C2 - Aerobic Gym	1
A06 - AHU C3 - Locker Rooms	1
A07 - AHU C4 - Office/Classroom	1
A09 - Project 2 - Wing D PFPMXB	1
A10 - AHU D2 - Classrooms	1

Pre-assigned "A Base Case" Air Systems

Figure 5.2c – Base Case Plant Configuration

Plant Properties - [A BASE CASE CW PLANT SIZING]

General **Systems** Service Hot Water Configuration Schedule of Eqpt Distribution Cond. Water

Equipment

Chiller Sizing: User-Specified Capacities

Number of Chillers: 2 Capacity Oversizing Factor: %

Cooling Controls

Plant Control: Equal Unloading

LCHWT Control: Constant LCHWT

Design LCHWT: 44.0 °F

... When OAT Above: °F

Maximum LCHWT: °F

... When OAT Below: °F

☐ Use Free Cooling

Type of Free Cooling: Heat Exchanger: °F

Cooling Tower: One tower for each water-cooled chiller

Plant Type: Chiller Plant

Number of units used in the plant: Min: 1 Max: 12

OK Cancel Help

Figure 5.2d – Schedule of Equipment

Plant Properties - [A SIZING]

General		Systems	Service Hot Water	Configuration	Schedule of Eqpt.	Distribution	Cond. Water
Sequence	Equipment	Full Load Capacity (Tons)	Cooler Flow Rate	Condenser Flow Rate	Cooling Tower	Tower Flow Rate	
CH-1	a air cooled import	133.3	318.7 gpm				
CH-2	a air cooled import	133.3	318.7 gpm				

Figure 5.2e – Configure Plant Distribution

Plant Properties - [A Base Case Chiller Plant]

General		Systems	Configuration	Schedule of Eqpt.	Distribution	Cond. Water
Distribution System			Fluid Properties			
Type	Primary Only, Variable Speed		Name: Fresh Water			
Coil Delta-T at Design	12.0 °F		Density: 62.4 lb/ft³			
Pipe Heat Gain Factor	2.0 %		Specific Heat: 1.00 BTU / (lb · °F)			
Pump Performance Units	ft wg					
Primary Loop						
	Flow Rate	Pump (ft wg)	Mech Efficiency (%)	Elec Efficiency (%)		
Design	610.2 gpm	70.0	75.0	94.0		
Control Head		10.0 ft wg				
Minimum Pump Flow		50.0 %				
Minimum Chiller Flow		50.0 %				
<p>1. Select Primary Only, Variable Speed from dropdown</p> <p>2. Enter 12F Coil Delta-T at Design</p> <p>3. Enter 2% Piping Heat Gain Factor</p> <p>4. Select ft.wg. from dropdown for Pump Performance Units</p> <p>5. Enter 70.0 ft. wg., 75% Mech and 94% Elec Efficiencies</p> <p>6. Enter 10.0 ft. Control Head, and 50% Min Pump and Chiller flows</p> <p>7. Click OK when finished</p>						
Click OK to exit and save any changes made to this Plant				<p>7 OK Cancel Help</p>		

Figure 5.2f – Base Case Boiler Plant Input






Figure 5.2g – A Base Case Air




Figure 5.2h – Boiler Plant Configuration




Figure 5.2i – Boiler Plant Schedule of Equipment

Plant Properties - [A Base Case Boiler Plant]

General Systems Configuration **Schedule of Eqpt.** Distribution Cond. Water

Sequence	Boiler Name	Capacity (MBH)	Hot Water Flow Rate
B-1	A Base Case Boilers 1	1800.0	30.0 °F
B-2	A Base Case Boilers	1800.0	30.0 °F

Totals:  
Est. Max Load:

Make All Equipment the Same

**BOILER PLANT CONFIGURATION FOR DISCUSSION ONLY**

1. Select A Base Case Boilers from dropdown

Figure 5.2j – Boiler Plant Distribution

Plant Properties - [A Base Case Boiler Plant]

General Systems Configuration Schedule of Eqpt. **Distribution** Cond. Water

Distribution System

Type Primary Only, Variable Speed 1

Coil Delta-T at Design 2 30.0 °F

Pipe Heat Loss Factor 3 2.0 %

Pump Performance Units ft wg 4

Primary Loop

	Flow Rate	Pump (ft wg)	Mech Efficiency (%)	Elec Efficiency (%)
Design	<Auto-s> 5	50.0	75.0	94.0

Control Head 6 10.0 ft wg

Minimum Pump Flow 7 30.0 %

Minimum Boiler Flow 30.0 %

Fluid Properties

Name Fresh Water

Density 60.6 lb/ft³

Specific Heat 1.00 BTU/(lb - °F)

Accept Fresh Water Fluid Properties defaults.

1. Select Primary Only, Variable Speed from Type dropdown  
 2. Enter 30.0 F Coil Delta-T at Design  
 3. Enter 2% Pipe Heat Loss Factor  
 4. Select ft.wg. from dropdown for Pump Performance Units  
 5. Enter 50.0 for Pump ft. wg., 75% Mech Efficiency and 94% Electrical Efficiency  
 6. Enter 10 ft. wg. for Control Head  
 7. Enter 30% Minimum Pump and Boiler Flow  
 8. Click OK when finished

8 OK Cancel Help

Click OK to exit and save any changes made to this Plant

This completes the base case plant inputs please refer to the chiller and boiler plant input reports for C Alt 2 to configure chiller and boiler plants. Use the same procedure for editing the plants



described in the base case above for the C Alt 2 plants. Refer to the following pages for the C Alt 2 plant details.

## C Alt 2 Chiller Plant Input Data

### 1. General Details:

Plant Name ..... C Alt 2-(1)30XW WC Screw Chiller  
Plant Type ..... Chiller Plant

### 2. Air Systems served by Plant:

Air System Name	Mult.
C01 - 4PFCU D1 - Wing A(all)	1
C02 - 4PFCU D1 - Wing B (all)	1
C03 - AHU C1- Gymnasium	1
C04 - AHU C2- Aerobic Gym	1
C05 - AHU C3 - Locker Rooms	1
C06 - 4PFCU C4 - Office/Classrm	1
C08 - 4PFCU D1 - Wing D (all)	1

**NOW LET'S DO THE  
'C' PLANT FINAL  
INPUTS!**

### 3. Configuration

Chiller Sizing ..... User-Specified Chiller Capacities  
Number of Chillers ..... 1  
Cooling Tower Configuration ..... One tower for each W/C chiller  
LCHWT Control ..... Constant LCHWT  
Design LCHWT ..... 44.0 °F  
Free Cooling ..... Not Used

### 4. Schedule of Equipment

Sequence	Chiller Name	Full Load Capacity (Tons)	Cooler Flow Rate	Condenser Flow Rate	Cooling Tower Name	Tower Flow Rate
CH-1	C Alt 2 WC Packaged Screw Chiller	222.5	534	668	C Alt 2 W/C Screw Cooling Tower	900
	Totals:	222.5	534 gpm	668	Totals:	900

### 5. Distribution

#### Distribution System

Type ..... Primary Only, Variable Speed  
Coil Delta-T at Design ..... 12.0 °F  
Pipe Heat Gain Factor ..... 2.0 %  
Pump Performance ..... ft wg

#### Fluid Properties

Name ..... Fresh Water  
Density ..... 62.4 lb/ft<sup>3</sup>  
Specific Heat ..... 1.00 BTU / (lb - °F)

#### Primary Loop

	Flow	Head (ft wg)	Mechanical Efficiency (%)	Electrical Efficiency (%)
Design	534	75.0	80	94.0

Control Head ..... 10.0 ft wg  
Minimum Pump Flow ..... 50 %  
Minimum Chiller Flow ..... 50 %

### 6. Condenser Water



**Condenser Water System**

Pump Control ..... CONSTANT FLOW

Pump Performance ..... ft wg

HEAD ..... 25.0 ft wg

**Condenser Water Loop**

Pump for...	Flow	Head (ft wg)	Mechanical Efficiency (%)	Electrical Efficiency (%)
CH-1	638	25	75.0	94.0

**C Alt 2 Hot Water Boiler Plant Input Data****1. General Details:**

Plant Name ..... C Alt 2 HW Boiler Plant

Plant Type ..... Hot Water Boiler Plant

**2. Air Systems served by Plant:**

Air System Name	Mult.
C01 - 4PFCU D1 - Wing A(all)	1
C02 - 4PFCU D1 - Wing B (all)	1
C03 - AHU C1- Gymnasium	1
C04 - AHU C2- Aerobic Gym	1
C05 - AHU C3 - Locker Rooms	1
C06 - 4PFCU C4 - Office/Classrm	1
C08 - 4PFCU D1 - Wing D (all)	1

**3. Configuration**

Boiler Sizing ..... User-Specified Boiler Capacities

Number of Boilers ..... 2

Plant Control ..... Sequenced

HWST Control ..... Constant HWST

Design HWST ..... 180.0 °F

**4. Schedule of Equipment**

Sequence	Boiler Name
B-1	C Alt 2 Boiler 1
B-2	C Alt 2 Boiler 2
	Totals:

**WE WILL NOT INCLUDE A  
BOILER PLANT SO  
DISREGARD ALL BOILER  
INPUTS**

Est. Max Load ..... 2403.5 Tons

**5. Distribution****Distribution System**

Type ..... Primary Only, Variable Speed

Coil Delta-T at Design ..... 30.0 °F

Pipe Heat Loss Factor ..... 2.0 %

Pump Performance ..... ft wg

**Fluid Properties**

Name ..... Fresh Water

Density ..... 60.6 lb/ft³

Specific Heat ..... 1.00 BTU / (lb - °F)

**Primary Loop**

	Flow	Head (ft. wg.)	Mechanical Efficiency (%)	Electrical Efficiency (%)
Design	<auto-sized>	50.0	75.0	94.0

Control Head ..... 10.0 ft wg  
 Minimum Pump Flow ..... 30.0 %  
 Minimum Boiler Flow ..... 30.0 %

**D Alt3 SZCV/RTU (ROOFTOP UNIT)**

Next let's look at how to configure a packaged roof top unit for energy simulation. Our "D" Alternative consists of 36 single zone, constant air volume packaged rooftop units with electric heating. **Open the Air System Properties form for [D31 – RTU D5 – Classroom D104] and review the following details required for an energy.**

Figure 5.3a – Packaged RTU-Configuration System Components –Supply Fan

**Air System Properties - [D31 - RTU D5 - Classroom D104]**

General | **System Components** | Zone Components | Sizing Data | Equipment

☒ Ventilation Air  
☒ Economizer  
☐ Vent. Reclaim  
☐ Precool Coil  
☐ Preheat Coil  
☐ Humidification  
☐ Dehumidification  
☒ Central Cooling  
☒ Central Heating  
☒ **Supply Fan**  
☒ Duct System  
☐ Return Fan

**Supply Fan**  
 Fan Type: Forward Curved  
 Configuration: ☒ Draw-Thru ☐ Blow-Thru  
 Total Static: 1.50 in. wg.  
 Overall Efficiency: 54 %

% Airflow	100	90	80	70	60	50
% KW						

% Airflow	40	30	20	10	0
% KW					

Fan Control: 2-speed fan cooling, 1-speed fan heating  
 Low Speed Fan Airflow: 67 %

**Select Fan Control and Airflow** [OK] [Cancel] [Help]

Figure 5.3b – Equipment – Central Cooling Unit

The screenshot shows the 'Central Cooling Unit - Air-Cooled DX' dialog box. The 'Equipment Data' tab is selected. The following fields are highlighted with numbered callouts:

- 1: Design OAT (95.0 °F)
- 2: Equipment Sizing (User-Defined Capacity)
- 3: Gross Cooling Capacity (55.1 MBH)
- 4: AHRI Performance Rating (15.200 SEER)
- 5: DX System Configuration (1-stage compression, 1 circuit)
- 6: Conventional Cutoff OAT (55.0 °F)
- 7: Low Temperature Operation (checked)
- 8: Low Temperature Cutoff OAT (0.0 °F)
- 9: OK button

At the bottom, there is a message: 'Click OK Button to Save Changes'.

Configure the central cooling unit air cooled DX Equipment as follows:

1. The Design OAT populates to ARI Standard conditions.
2. Equipment capacity defaults to auto-sized, however, we recommend entering actual selected equipment manufacturer's performance data by selecting "User-Defined Capacity" from Equipment Sizing dropdown.
3. Enter Gross Cooling Capacity from manufactures performance data
4. Select AHRI Performance Rating from dropdown and enter the SEER or EER efficiency
5. Select DX Configuration from dropdown
6. Enter Conventional Cutoff OAT
7. Leave Low Temperature Operation checkbox checked
8. Enter the Low Ambient Temperature Cutoff Outdoor Temperature
9. Click OK to save



Figure 5.3c Central Heating Unit

**Equipment Data**

Estimated Maximum Load  MBH

Equipment Sizing  ①

Gross Heating Capacity  ②

Capacity Oversizing Factor  %

Average Efficiency  ③

Misc. Electric  ④

**ELECTRIC HEAT HAS ALREADY BEEN CONFIGURED IN THE ARCHIVE FOR THE RTU.**

1. Select Equipment Sizing preference from dropdown  
2. Enter the Gross Heating Capacity  
3. Enter the AFUE percent  
4. Enter Misc. Electric energy use in kW (draft blower etc.)  
5. Click OK when finished

⑤

Click OK Button to Save Changes

After entering the plant and equipment data, we can generate the Simulation Reports for the cooling plants and packaged RTU. Please refer to the following pages for the detailed simulation reports for "A" Base Case Chiller plant, AND Classroom D104 rooftop unit.

# Workshop 5 Solutions





## RUN THESE REPORTS FOR THE A BASE AIR COOLED CHILLER PLANT

**Plant Simulation Reports**

Reports	Table	Graph	TXT	Time Specifications
Monthly Simulation Results	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	For <input type="text" value="August"/> From <input type="text" value="Aug. 26"/> To <input type="text" value="Aug. 27"/>
Daily Simulation Results	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Hourly Simulation Results	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Unmet Loads Report	<input checked="" type="checkbox"/>	--	--	

**Graph Specifications**

☐ Cooling Coil Load (kBTU)  
☒ Plant Cooling Load (kBTU)  
☐ Primary Water Dist. Pump (kWh)  
☒ Chiller Output (kBTU)  
☐ Chiller Input (kWh)

Select up to 3 data items for the graph. All must have the same units of measure.

Note: Graph options are only available when a single plant has been selected and that plant was previously simulated.




## Workshop 5 Solutions

### Monthly Simulation Results for A SIZING

TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 wk thru  
carrier

Plant Simulation Results (Table 1) :

Month	Cooling Coil Load (kBTU)	Plant Cooling Load (kBTU)	Chiller Output (kBTU)	Chiller Input (kWh)	Primary Water Dist. Pump (kWh)
January	616710	635335	635335	49242	2492
February	618105	636255	636255	50354	2278
March	761172	783274	783274	63010	2650
April	773003	795584	794258	64747	2696
May	858546	883708	880080	71862	2965
June	526790	544176	542441	44039	2631
July	119591	127550	127550	11262	2307
August	854071	879382	874202	70962	3035
September	890346	916702	897665	73721	3110
October	882267	908352	895849	72316	3098
November	860852	886092	876320	69179	2956
December	713851	734695	734695	56492	2566
Total	8475301	8731105	8677925	697186	32784



## Daily Plant Simulation Results for August (Table 1) :

Daily Simulation Results for A SIZING	
TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 wk thru carrier	07/25/2017 08:26PM

## Daily Plant Simulation Results for August (Table 1) :

Day	Cooling Coil Load (kBTU)	Plant Cooling Load (kBTU)	Chiller Output (kBTU)	Chiller Input (kW/h)	Primary Water Dist. Pump (kW/h)
1	5074	5355	5355	465	74
2	40868	42047	41095	3298	125
3	37930	39007	38777	3174	113
4	36946	37985	37985	3075	107
5	39203	40326	39526	3184	119
6	32900	33806	33806	2588	92
7	12382	12810	12810	1042	74
8	3087	3328	3328	310	74
9	37777	38851	38818	3145	112
10	34656	35618	35618	2671	98
11	33702	34633	34633	2770	95
12	33777	34715	34715	2805	96
13	36495	37623	37523	3039	107
14	14235	14699	14699	1222	74
15	3382	3630	3630	346	74
16	37586	38648	38648	3143	110
17	36253	37276	37174	2944	107
18	37130	38180	38128	3165	110
19	37236	38300	37897	3045	113
20	36377	37407	37407	3082	108
21	14888	15365	15365	1279	74
22	3766	4021	4021	395	74
23	40715	41888	40938	3411	124
24	37634	38907	38795	3203	112
25	34356	35326	35177	2788	103
26	35795	36798	36798	2971	103
27	36313	39399	39277	3253	113
28	14716	15190	15190	1232	74
29	3309	3555	3555	332	74
30	40313	41478	40202	3247	125
31	3069	3310	3310	338	74
Total	854071	879382	874202	70962	3035




Daily Simulation Results for A SIZING

TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 wk thru  
carrier

07/25/2017  
08:26PM

Daily Simulation Results for August



## [ENERGY SIMULATION]

### Hourly Simulation Results for A SIZING

TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 WK thru  
carrier

07/25/2017  
08:26PM

Table 1.1 Hourly Plant Simulation Results for Thursday, August 26

Hour	Cooling Coil Load (MBH)	Plant Cooling Load (MBH)	Chiller Output (MBH)	Chiller Input (kW)	Primary Water Dist. Pump (kW)
0000	95.5	104.9	104.9	8.7	3.1
0100	93.6	103.0	103.0	8.6	3.1
0200	91.4	100.7	100.7	8.4	3.1
0300	91.6	100.9	100.9	8.4	3.1
0400	91.5	100.8	100.8	8.2	3.1
0500	91.6	100.9	100.9	8.4	3.1
0600	1739.0	1781.3	1781.3	133.0	3.1
0700	2494.5	2558.0	2558.0	202.5	4.7
0800	2907.2	2985.2	2985.2	233.9	6.5
0900	2687.1	2964.4	2964.4	233.8	6.4
1000	2644.4	2920.1	2920.1	232.1	6.2
1100	3039.1	3122.1	3122.1	262.0	7.2
1200	2659.8	2728.9	2728.9	237.9	5.3
1300	2977.6	3058.3	3058.3	259.4	6.9
1400	2634.5	2909.6	2909.6	242.9	6.1
1500	2683.8	2753.7	2753.7	223.5	5.4
1600	2502.7	2566.4	2566.4	206.5	4.7
1700	2140.7	2193.0	2193.0	169.9	3.6
1800	826.7	850.7	850.7	65.1	3.1
1900	835.1	859.3	859.3	66.2	3.1
2000	841.9	866.3	866.3	66.4	3.1
2100	824.4	848.4	848.4	64.9	3.1
2200	100.6	110.1	110.1	9.9	3.1
2300	101.0	110.5	110.5	9.8	3.1
Total	35795.2	36797.9	36797.9	2970.6	103.3

## Hourly Simulation Results for A SIZING

TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 wk thru  
carrier07/25/2017  
08:26PM

Table 2.1 Hourly Plant Simulation Results for Friday, August 27

Hour	Cooling Coil Load (MBH)	Plant Cooling Load (MBH)	Chiller Output (MBH)	Chiller Input (kW)	Primary Water Dist. Pump (kW)
0000	100.5	110.0	110.0	9.7	3.1
0100	100.4	109.9	109.9	9.5	3.1
0200	102.0	111.5	111.5	9.9	3.1
0300	103.1	112.6	112.6	10.2	3.1
0400	105.3	114.9	114.9	10.5	3.1
0500	107.4	117.1	117.1	10.9	3.1
0600	2312.2	2369.8	2369.8	181.8	4.1
0700	2471.4	2534.1	2534.1	197.7	4.6
0800	2961.5	3041.6	3041.6	240.8	6.8
0900	3011.7	3093.7	3093.7	251.2	7.0
1000	3074.5	3158.9	3158.9	262.8	7.4
1100	3127.8	3214.3	3199.2	272.5	7.7
1200	2704.8	2775.5	2775.5	241.6	5.5
1300	3099.3	3184.7	3184.7	271.2	7.5
1400	3169.6	3257.8	3199.2	279.2	8.0
1500	3159.5	3247.3	3199.2	279.2	7.9
1600	2693.6	2763.9	2763.9	227.5	5.5
1700	2216.7	2271.4	2271.4	183.1	3.8
1800	924.2	950.2	950.2	77.1	3.1
1900	875.8	900.8	900.8	71.9	3.1
2000	871.0	895.9	895.9	70.2	3.1
2100	828.0	852.1	852.1	65.2	3.1
2200	95.1	104.5	104.5	9.5	3.1
2300	97.2	106.6	106.6	9.5	3.1
Total	38312.6	39399.1	39277.4	3252.6	113.0



### 1. Unmet Load Statistics - Central Cooling Unit - Air-Cooled DX

Note: Data shown in this report is for diagnostic purposes only. Values represent total unmet hours for each cooling and/or heating unit. No deductions are made when unmet hours for one unit coincide with those in another unit.

#### 1. Unmet Load Statistics - Central Cooling Unit - Air-Cooled DX

Month	Equipment Capacity is Sufficient (hrs)	Capacity Insufficient by 0%-5% (hrs)	Capacity Insufficient by 5%-10% (hrs)	Capacity Insufficient by >10% (hrs)	Total Hours with Unmet Loads	Total Hours with Equipment Loads
January	296	0	0	0	0	296
February	316	0	0	0	0	316
March	376	0	0	0	0	376
April	417	4	0	0	4	421
May	440	4	1	0	5	445
June	422	0	0	0	0	422
July	541	0	0	0	0	541
August	401	16	2	0	18	419
September	361	18	23	4	45	406
October	384	19	7	0	26	410
November	328	3	1	3	7	335
December	328	0	0	0	0	328
<b>Total</b>	<b>4610</b>	<b>64</b>	<b>34</b>	<b>7</b>	<b>105</b>	<b>4715</b>

### 1. Zone Temperature Statistics

# [ENERGY SIMULATION]

## Zone Temperature Report for D03 - RTU A3 - Principal/Conf

Project Name: TRINIDAD ENERGY ARCHIVE 2 UNSOLVED 2017 wk thru  
Prepared by: carrier

07/25/2017  
08:42PM

### 1. Zone Temperature Statistics

	Occ	Occ	Occ	Occ	Occ	Occ	Occ	Occ	Occ	Unocc	Unocc	Unocc	Unocc
	Max Zone Temp (°F)	Hours More Than 5.0 °F Above Throt. Range	Hours 1.0 to 5.0 °F Above Throt. Range	Cooling Setpoint plus Throt. Range (°F)	Hours Within Throt. Range or Dead- band	Heating Setpoint minus Throt. Range (°F)	Hours 1.0 to 5.0 °F Below Throt. Range	Hours More Than 5.0 °F Below Throt. Range	Min Zone Temp (°F)	Max Zone Temp (°F)	Cooling Setpoint plus Throt. Range (°F)	Heating Setpoint minus Throt. Range (°F)	Min Zone Temp (°F)
Zone Name													
A104-Asst. Prin.	74.4	0	0	74.0	2724	68.0	0	0	72.2	82.5	84.0	63.0	76.0

Note: For any occupied hours in which cooling is unavailable or scheduled off, zone temperature out of range statistics are not reported.

Note: For any occupied hours in which heating is unavailable or scheduled off, zone temperature out of range statistics are not reported.

Note: For any occupied hours in which cooling is unavailable or scheduled off, zone temperature out of range statistics are not reported.

Note: For any occupied hours in which heating is unavailable or scheduled off, zone temperature out of range statistics are not reported.

# Workshop 6 Inputs





Blank Page

Blank Page

## Workshop 6 Defining and Simulating Buildings



### Defining Buildings in HAP

**The first step in this workshop is to retrieve Trinidad Energy Archive 3 Unsolved from the Unsolved Loads and Energy folder on your desktop. Before we start working with this archive, let us discuss how HAP uses the term “building”.**

A building in HAP is the “container” for all HVAC and non-HVAC systems for one design scenario. Performing an energy analysis calculates annual energy costs for the building’s energy consuming systems. System design load analysis in HAP, requires us to create elements, spaces, zones, air systems, and plants like in the previous workshops, while a “building” is only required for performing an energy simulation.

Taken literally, a building represents one structure. However, in HAP the definition of a building is flexible. It can also represent a group of structures. For example, a “building” could represent a campus in which all the structures are served by central steam and chilled water plant equipment. Keep in mind, a design case can contain part of an actual building, a complete building, or many buildings.

When using the Equipment Wizard HAP not only creates the Air Systems and Plants but also a Building. The Wizard created Building includes the plants, air systems, spaces and all items linked to the spaces like schedules, construction items etc.

One exercise included in this workshop is defining the Energy Charges by creating a Fuel Rate and Electric Rate. There are several ways to create these energy rates including the Utility Rate Wizard, importing previously created rates, use the USA state EIA average rates or user defining the rates. For our workshop we create a complex electric rate that includes seasonal scheduling, time-of-day utility rate schedules and demand clause. Create the Natural Gas utility rate as a simple rate structure. Use the following values for creating the electric and fuel utility rates.

#### Electric Rate

Rate Name .....  
Rate Type .....

#### Electric Rate Details

##### Electric Rate Setup

Rate Name .....  
Customer Charge .....  
Seasonal Pricing .....  
Time of Day Pricing .....

#### Energy Charge

Type ..... Flat Prices

#### Demand Charge

Type ..... Flat Prices

#### Emission Factors

CO<sub>2</sub>e Emissions ..... 1.575 lb/kWh

**WE WILL DO A PRACTICE  
“DETAILED” ELECTRIC  
AND FUEL RATE...USING  
THE UTILITY RATE  
WIZARD... SEE THE  
HANDOUT!**



**Blank Page**

## Electric Rate Schedules

### Seasonal Pricing

	Summer	Winter
Start	May	Oct
End	Sept	April

### Time of Day Pricing

	Summer		Winter	
	Peak Start	Off Peak Start	Peak Start	Off Peak Start
Weekdays	9 AM	9 PM	9 AM	9 PM
Saturday	None	All	None	All
Sunday/Hol	None	All	None	All

**WE WILL CONFIGURE THIS EXAMPLE ELECTRIC RATE WITH THE UTILITY RATE WIZARD...SEE THE HANDOUT FOR THE INFO TO CONFIGURE!**

## Electric Energy and Demand Charges

### Electric Energy Charge

Season	Period	Block Size (kWh)	Price (\$/kWh)
Summer	Peak	All	0.08000
Summer	Off-Peak	All	0.06500
Winter	Peak	All	0.07000
Winter	Off-Peak	All	0.05500

### Electric Demand Charge

Season	Period	Block Size (kW)	Price (\$/kW)
Summer	Peak	All	12.00000
Summer	Off-Peak	All	10.00000
Winter	Peak	All	9.00000
Winter	Off-Peak	All	6.00000

### Ratchet Clause

Ratchet Clause .....	Used
Peak Month Start .....	May
Peak Month End .....	Sept
Ratchet Applies Start .....	Oct
Ratchet Applies End .....	May
Multiplier .....	80 %
<b>Minimum Demand</b>	
Minimum Demand .....	25 kW

## Fuel Rates

### Natural Gas

Rate Name .....	Gas Rate
Units of Measure .....	MCF
Conversion Factor .....	1000.00000 kBTU/MCF
Fuel Price .....	12.28000 \$/MCF
CO2e Emissions .....	122.000 lb/MCF

Refer to Figures 6.1a through 6.1c for details.

Figure 6.1a – Utility Rate Wizard Input Form Screen 1

Utility Rate Wizard

**THIS SHOWS THE WIZARD RESULTS**

Electric Rate Setup

Rate Name

Customer Charge 50.00 \$/month

☒ Seasonal Pricing ☒ Time of Day Pricing

Energy Charge

Type Flat Prices

Steps

Demand Charge

Type Flat Prices

Steps

CO2e Emission Factor 1.575 lb/kWh

	Summer		Winter	
Start	May		Oct	
End	Sept		April	

Time of Day Pricing

	Summer		Winter	
	Peak Start	Off-Peak Start	Peak Start	Off-Peak Start
Weekdays	9 AM	9 PM	9 AM	9 PM
Saturday	None	All	None	All
Sunday/Hol	None	All	None	All


Details Screen: 1 of 2

Help Previous **Next** Finish Cancel



Figure 6.1b - Utility Rate Wizard Input Form Screen 2

Utility Rate Wizard



**Electric Energy Charge**

Season	Period	Block Size (kWh)	Price (\$/kWh)
Summer	Peak	All	0.08000
Summer	Off-Peak	All	0.06500
Winter	Peak	All	0.07000
Winter	Off-Peak	All	0.05500

**Electric Demand Charge**

Season	Period	Block Size (kW)	Price (\$/kW)
Summer	Peak	All	12.00000
Summer	Off-Peak	All	10.00000
Winter	Peak	All	9.00000
Winter	Off-Peak	All	6.00000

☒ Ratchet Clause

Peak Months: May to Sept

Ratchet Applies: Oct to May

Multiplier: 80 %

Minimum Demand: 25 kW

Details Screen: 2 of 2

Help Previous Next **Finish** Cancel

Figure 6.1c – Utility Rate Wizard Natural Gas Utility Rate

Utility Rate Wizard

**Electric Rate**

Rate Name: **THIS SHOWS THE WIZARD RESULTS**

Rate Type: Detailed

View / Edit Detailed Inputs

Energy Charge: Flat Prices.  
Demand Charge: Flat Prices.  
Demand Determination: Ratchet clause used.  
Minimum demand clause used.

**Fuel Rates**

☒ Natural Gas

Rate Name: Gas Rate

Units of Measure: MCF

Conversion Factor: 1000.00000 kBTU/MCF

Price: 12.28000 \$/MCF

CO2e Emissions: 122.000 lb/MCF

☐ Fuel Oil

☐ Propane

Help Finish Cancel

**Now that we have completed an exercise in “detailed” utility rate modeling, we will use a simple flat rate of \$0.03 per kWh for Trinidad. Let’s configure the 4 building scenarios for Trinidad first....then...**

**We can then re-run this project in these locations and use these rates:**

**1. Curacao:**

**Electricity Cost \$ 0.30 cent / kWh**

**All Electric**

**2. Barbados:**

**Electricity Cost \$ 0.35 cent / kWh**

**Fuel: Natural Gas**





Our next exercise in this workshop consists of creating the “Buildings” for this project. As discussed in a previous paragraph, each “Building” represents a design alternative for comparison of energy consumption etc. Our project includes the following four (4) designs:

**I. Building Name: A Base VAV-PFPMXB- 62.1-2007**

Cooling Plant: (2) 30 XA Air- Cooled Chillers  
Heating: Electric  
Air Systems: A01-A10  
Air System Types: VAV PFPMXB, SZCV  
Ventilation Control: Constant  
Ventilation Sizing: ASHRAE 62.1-2007

**II. Building Name: B Alt1 VAV-PFPMXB- DCV**

Cooling Plant: (2) 30 XA Air- Cooled Chillers  
Heating Plant: Electric  
Air Systems: B01-B10  
Air System Types: VAV PFPMXB, SZCV  
Ventilation Control: *Demand Controlled Ventilation*  
Ventilation Sizing: ASHRAE 62.1-2007

**III. Building Name: C Alt2-4PFCU- DOAS– 62.1-2007**

Cooling Plant: (1) 23 XRV Water-Cooled Screw Chiller  
Heating Plant: Electric  
Air Systems: C1-C8  
Air System Types: 4- Pipe Fan Coil Units, SZCV  
Ventilation Control: Constant (dedicated ventilation for 4PFCU)  
Ventilation Sizing: ASHRAE 62.1-2007

**IV. Building Name: D Alt3 SZCV/RTU- 62.1-2007**

Cooling Plant: None (Integral to RTU- Air Cooled DX)  
Heating Plant: None (Integral to RTU –Electric Resistance)  
Air Systems: D01-D36  
Air System Types: SZCV RTU  
Ventilation Control: Constant  
Ventilation Sizing: ASHRAE 62.1-2007

Notice the “B Alt-1” scenario is a duplicate of the “A” Base Case except the associated air systems use demand control ventilation to size ventilation loads. Using DCV is an energy saving strategy that reduces ventilation air requirements resulting from diverse building occupancy. The “C Alt-2” design scenario uses a water cooled screw chiller to supply chilled water to 2-pipe fan coil units and single zone air handlers. The fan coil systems utilize a common (dedicated) ventilation air system resulting in a lower peak total ventilation airflow compared to the A and B scenarios.

The “D-Alt 3” scenario uses multiple packaged single zone constant volume RTU units. The rooftop units are self-contained DX cooling with electric heating and are not connected to a chilled water or hot water plant.

In order to save time, the schedules and profiles applicable to the miscellaneous energy items are completed as part of archive # 3.

Figure 6.2 – Enter Building Data

Building Properties - [A-Base VAV-PFPMXB- 62.1-2007]

Plants Systems Misc. Energy Meters

General

Building Name: 1 A-Base VAV-PFPMXB- 62.1-2007

Plants Included in Building

2

1. Ent


2. Select the Plants to include in the Building Design

WE WILL CONFIGURE THE 4 BUILDINGS INCLUDING THE SERVICE HOT WATER PLANT FOR TRINIDAD AT \$.03 PER KWH.

OK Cancel Help



Figure 6.3 – Assign Air Systems to Building Design



**Enter the following Miscellaneous Energy Users under the Misc. Energy Tab.** Refer to Figure 6.4 for additional details. Note: the fractional schedules came as part of the archive, there is no need to create the fractional schedules for this exercise

Name	Energy Type	Peak Use	Schedule
Exterior Lighting	Electric	5.0kW	Parking Lot Lights
Aerobic Pool Heater	Electric	200 KW	Aerobic Pool Heater
Pool Circ. Pumps	Electric	2.5 kW	Aerobic Pool Heater

Figure 6.4 – Misc. Energy Tab Input Details

Name	Process Load	Energy or Fuel Type	Peak Use	Schedule	Edit
Exterior Lighting	<input type="checkbox"/>	Electric	5.0 kW	Parking Lot Lights	Edit
Domestic Water Heating	<input type="checkbox"/>			ting	Edit
Pool Heater	<input type="checkbox"/>				Edit
Domestic Water Circ Pump	<input type="checkbox"/>			ting	Edit
Pool Circ Pump	<input type="checkbox"/>	Electric	2.5 kW	Aerobic Pool Heater	Edit
	<input type="checkbox"/>	Electric	0.0 kW	none	Edit
	<input type="checkbox"/>	Electric	0.0 kW	none	Edit
	<input type="checkbox"/>	Electric	0.0 kW	none	Edit
	<input type="checkbox"/>	Electric	0.0 kW	none	Edit
	<input type="checkbox"/>	Electric	0.0 kW	none	Edit

OK Cancel Help

Figure 6.5 – Building Meters Tab

**Meters**

Electric

Natural Gas

Fuel Oil

Propane

Remote Hot Water: <none>

Remote Steam: <none>

Remote Chilled Water: <none>

**Miscellaneous Data**

Average Building Power Factor: 100.00 %

Source Electric Generating Efficiency: 28.00 %

Additional Floor Area: 0.0 ft²

OK Cancel Help



Highlight the “A Base Case Building” after saving it and then right mouse click and choose Duplicate.

Rename the duplicate B ALT1 VAV FPMXB DCV. Deselect the A Base Case plant and assign the B plant to the B Building under the Plants Tab. Refer to Figure 6.6 for details.

Figure 6.6 – B Alt 1 Building Properties - Plants








Figure 6.7 – B Alt 1 Building Properties – Systems



These are the only required changes for the B Alt 1 Building design. Repeat the process for the C Alt 2 design and D Alt 3 Design. After saving these additional buildings, highlight all four design case buildings and perform the energy simulation.

# Workshop 6 Solutions



Blank Page



## Simulation Results

Table 1. Annual Costs

Component	A AC CHILLERS (\$)	B AC CHILLERS DCV (\$)	C WC CHILLER (\$)	D RTUS (\$)
Air System Fans	7,228	7,228	4,717	6,898
Cooling	21,650	17,824	12,387	17,679
Heating	2,346	2,346	1,247	1,247
Pumps	985	901	1,479	2
Heat Rejection Fans	0	0	1,823	0
<b>HVAC Sub-Total</b>	<b>32,209</b>	<b>28,299</b>	<b>21,653</b>	<b>25,825</b>
Lights	7,311	7,311	7,311	7,311
Electric Equipment	3,568	3,568	3,569	3,569
Misc. Electric	10,070	10,070	10,070	10,070
Misc. Fuel Use	0	0	0	0
<b>Non-HVAC Sub-Total</b>	<b>20,949</b>	<b>20,949</b>	<b>20,949</b>	<b>20,950</b>
<b>Grand Total</b>	<b>53,159</b>	<b>49,248</b>	<b>42,603</b>	<b>46,775</b>

Table 2. Annual Cost per Unit Floor Area

Component	A AC CHILLERS (\$/ft <sup>2</sup> )	B AC CHILLERS DCV (\$/ft <sup>2</sup> )	C WC CHILLER (\$/ft <sup>2</sup> )	D RTUS (\$/ft <sup>2</sup> )
Air System Fans	0.105	0.105	0.068	0.100
Cooling	0.314	0.258	0.179	0.256
Heating	0.034	0.034	0.018	0.018
Pumps	0.014	0.013	0.021	0.000
Heat Rejection Fans	0.000	0.000	0.026	0.000
<b>HVAC Sub-Total</b>	<b>0.467</b>	<b>0.410</b>	<b>0.314</b>	<b>0.374</b>
Lights	0.106	0.106	0.106	0.106
Electric Equipment	0.052	0.052	0.052	0.052
Misc. Electric	0.146	0.146	0.146	0.146
Misc. Fuel Use	0.000	0.000	0.000	0.000
<b>Non-HVAC Sub-Total</b>	<b>0.303</b>	<b>0.303</b>	<b>0.303</b>	<b>0.303</b>
<b>Grand Total</b>	<b>0.770</b>	<b>0.713</b>	<b>0.617</b>	<b>0.677</b>
Gross Floor Area (ft <sup>2</sup> )	69057.0	69057.0	69057.0	69057.0
Conditioned Floor Area (ft <sup>2</sup> )	69057.0	69057.0	69057.0	69057.0

Note: Values in this table are calculated using the Gross Floor Area.

Table 3. Component Cost as a Percentage of Total Cost

Component	A AC CHILLERS (%)	B AC CHILLERS DCV (%)	C WC CHILLER (%)	D RTUS (%)
Air System Fans	13.6	14.7	11.1	14.7
Cooling	40.7	36.2	29.1	37.8
Heating	4.4	4.8	2.9	2.7
Pumps	1.9	1.8	3.5	0.0
Heat Rejection Fans	0.0	0.0	4.3	0.0
<b>HVAC Sub-Total</b>	<b>60.6</b>	<b>57.5</b>	<b>50.8</b>	<b>55.2</b>
Lights	13.8	14.8	17.2	15.6
Electric Equipment	6.7	7.2	8.4	7.6
Misc. Electric	18.9	20.4	23.6	21.5
Misc. Fuel Use	0.0	0.0	0.0	0.0
<b>Non-HVAC Sub-Total</b>	<b>39.4</b>	<b>42.5</b>	<b>49.2</b>	<b>44.8</b>
<b>Grand Total</b>	<b>100.0</b>	<b>100.0</b>	<b>100.0</b>	<b>100.0</b>

## Annual Emissions Summary

Table 1. Annual Costs

Component	A AC CHILLERS (\$)	B AC CHILLERS DCV (\$)	C WC CHILLER (\$)	D RTUS (\$)
<b>HVAC Components</b>				
Electric	32,210	28,299	21,652	25,826
Natural Gas	0	0	0	0
Fuel Oil	0	0	0	0
Propane	0	0	0	0
Remote HW	0	0	0	0
Remote Steam	0	0	0	0
Remote CW	0	0	0	0
<b>HVAC Sub-Total</b>	<b>32,210</b>	<b>28,299</b>	<b>21,652</b>	<b>25,826</b>
<b>Non-HVAC Components</b>				
Electric	20,950	20,950	20,949	20,948
Natural Gas	0	0	0	0
Fuel Oil	0	0	0	0
Propane	0	0	0	0
Remote HW	0	0	0	0
Remote Steam	0	0	0	0
<b>Non-HVAC Sub-Total</b>	<b>20,950</b>	<b>20,950</b>	<b>20,949</b>	<b>20,948</b>
<b>Grand Total</b>	<b>53,160</b>	<b>49,250</b>	<b>42,602</b>	<b>46,774</b>

Table 2. Annual Energy Consumption

Component	A AC CHILLERS	B AC CHILLERS DCV	C WC CHILLER	D RTUS
<b>HVAC Components</b>				
Electric (kWh)	1,073,650	943,315	721,746	860,852
Natural Gas (na)	0	0	0	0
Fuel Oil (na)	0	0	0	0
Propane (na)	0	0	0	0
Remote HW (na)	0	0	0	0
Remote Steam (na)	0	0	0	0
Remote CW (na)	0	0	0	0
<b>Non-HVAC Components</b>				
Electric (kWh)	698,341	698,341	698,315	698,281
Natural Gas (na)	0	0	0	0
Fuel Oil (na)	0	0	0	0
Propane (na)	0	0	0	0
Remote HW (na)	0	0	0	0
Remote Steam (na)	0	0	0	0
<b>Totals</b>				
Electric (kWh)	1,771,992	1,641,656	1,420,061	1,559,133
Natural Gas (na)	0	0	0	0
Fuel Oil (na)	0	0	0	0
Propane (na)	0	0	0	0
Remote HW (na)	0	0	0	0
Remote Steam (na)	0	0	0	0
Remote CW (na)	0	0	0	0

Table 3. Annual Emissions

Component	A AC CHILLERS	B AC CHILLERS DCV	C WC CHILLER	D RTUS
CO2 Equivalent (lb)	2,799,692	2,593,757	2,243,730	2,463,447



Table 4. Annual Cost per Unit Floor Area

Component	A AC CHILLERS (\$/ft <sup>2</sup> )	B AC CHILLERS DCV (\$/ft <sup>2</sup> )	C WC CHILLER (\$/ft <sup>2</sup> )	D RTUS (\$/ft <sup>2</sup> )
<b>HVAC Components</b>				
Electric	0.466	0.410	0.314	0.374
Natural Gas	0.000	0.000	0.000	0.000
Fuel Oil	0.000	0.000	0.000	0.000
Propane	0.000	0.000	0.000	0.000
Remote HW	0.000	0.000	0.000	0.000
Remote Steam	0.000	0.000	0.000	0.000
Remote CW	0.000	0.000	0.000	0.000
<b>HVAC Sub-Total</b>	<b>0.466</b>	<b>0.410</b>	<b>0.314</b>	<b>0.374</b>
<b>Non-HVAC Components</b>				
Electric	0.303	0.303	0.303	0.303
Natural Gas	0.000	0.000	0.000	0.000
Fuel Oil	0.000	0.000	0.000	0.000
Propane	0.000	0.000	0.000	0.000
Remote HW	0.000	0.000	0.000	0.000
Remote Steam	0.000	0.000	0.000	0.000
<b>Non-HVAC Sub-Total</b>	<b>0.303</b>	<b>0.303</b>	<b>0.303</b>	<b>0.303</b>
<b>Grand Total</b>	<b>0.770</b>	<b>0.713</b>	<b>0.617</b>	<b>0.677</b>
Gross Floor Area (ft <sup>2</sup> )	69057.0	69057.0	69057.0	69057.0
Conditioned Floor Area (ft <sup>2</sup> )	69057.0	69057.0	69057.0	69057.0

Note: Values in this table are calculated using the Gross Floor Area.

Table 5. Component Cost as a Percentage of Total Cost


Component	A AC CHILLERS (%)	B AC CHILLERS DCV (%)	C WC CHILLER (%)	D RTUS (%)
<b>HVAC Components</b>				
Electric	60.6	57.5	50.8	55.2
Natural Gas	0.0	0.0	0.0	0.0
Fuel Oil	0.0	0.0	0.0	0.0
Propane	0.0	0.0	0.0	0.0
Remote HW	0.0	0.0	0.0	0.0
Remote Steam	0.0	0.0	0.0	0.0
Remote CW	0.0	0.0	0.0	0.0
<b>HVAC Sub-Total</b>	<b>60.6</b>	<b>57.5</b>	<b>50.8</b>	<b>55.2</b>
<b>Non-HVAC Components</b>				
Electric	39.4	42.5	49.2	44.8
Natural Gas	0.0	0.0	0.0	0.0
Fuel Oil	0.0	0.0	0.0	0.0
Propane	0.0	0.0	0.0	0.0
Remote HW	0.0	0.0	0.0	0.0
Remote Steam	0.0	0.0	0.0	0.0
<b>Non-HVAC Sub-Total</b>	<b>39.4</b>	<b>42.5</b>	<b>49.2</b>	<b>44.8</b>
<b>Grand Total</b>	<b>100.0</b>	<b>100.0</b>	<b>100.0</b>	<b>100.0</b>

## Annual Component Cost for C Alt 2

### Annual Component Costs - C WC CHILLER

TRINIDAD ENERGY ARCHIVE 3 UNSOLVED 2017 WK THRU  
carrier

07/29/2017  
07:54AM



#### 1. Annual Costs

## 1. Annual Costs

Component	Annual Cost (\$)	(\$/ft <sup>2</sup> )	Percent of Total (%)
Air System Fans	4,717	0.068	11.1
Cooling	12,387	0.179	29.1
Heating	1,247	0.018	2.9
Pumps	1,479	0.021	3.5
Heat Rejection Fans	1,823	0.026	4.3
<b>HVAC Sub-Total</b>	<b>21,653</b>	<b>0.314</b>	<b>50.8</b>
Lights	7,311	0.106	17.2
Electric Equipment	3,569	0.052	8.4
Misc. Electric	10,070	0.146	23.6
Misc. Fuel Use	0	0.000	0.0
<b>Non-HVAC Sub-Total</b>	<b>20,949</b>	<b>0.303</b>	<b>49.2</b>
<b>Grand Total</b>	<b>42,603</b>	<b>0.617</b>	<b>100.0</b>

Note: Cost per unit floor area is based on the gross building floor area.

Gross Floor Area ..... 69057.0 ft<sup>2</sup>  
 Conditioned Floor Area ..... 69057.0 ft<sup>2</sup>

**FROM THIS POINT  
 FORWARD WE WILL NOT  
 REFER TO ANY OPERATING  
 COST RESULTS IN THE  
 MANUAL.**

**WE WILL EXAMINE OUR  
 RESULTS FOR TRINIDAD....**




## [ENERGY SIMULATION]

Component	Annual Cost (\$/yr)	(\$/ft <sup>2</sup> )	Percent of Total (%)
<b>HVAC Components</b>			
Electric	56,374	0.816	31.8
Natural Gas	33,262	0.482	18.8
Fuel Oil	0	0.000	0.0
Propane	0	0.000	0.0
Remote Hot Water	0	0.000	0.0
Remote Steam	0	0.000	0.0
Remote Chilled Water	0	0.000	0.0
<b>HVAC Sub-Total</b>	<b>89,636</b>	<b>1.298</b>	<b>50.6</b>
<b>Non-HVAC Components</b>			
Electric	61,823	0.895	34.9
Natural Gas	25,725	0.373	14.5
Fuel Oil	0	0.000	0.0
Propane	0	0.000	0.0
Remote Hot Water	0	0.000	0.0
Remote Steam	0	0.000	0.0
<b>Non-HVAC Sub-Total</b>	<b>87,548</b>	<b>1.268</b>	<b>49.4</b>
<b>Grand Total</b>	<b>177,184</b>	<b>2.566</b>	<b>100.0</b>

Note: Cost per unit floor area is based on the gross building floor area.






Gross Floor Area ..... 69057.0 ft<sup>2</sup>  
 Conditioned Floor Area ..... 69057.0 ft<sup>2</sup>

### Annual Cost HVAC and Non-HVAC




## Appendix "A" Air System Schematics


# Air System Schematics



## AIR SYSTEM SCHEMATICS CONSTANT VOLUME - SINGLE ZONE C.A.V.




## AIR SYSTEM SCHEMATICS CONSTANT VOLUME - C.A.V. REHEAT








## AIR SYSTEM SCHEMATICS CONSTANT VOLUME - MULTIZONE



## AIR SYSTEM SCHEMATICS CONSTANT VOLUME - BYPASS MULTIZONE




# AIR SYSTEM SCHEMATICS CONSTANT VOLUME - DUAL DUCT C.A.V.




CAV Tempering Ventilation System Schematic

## AIR SYSTEM SCHEMATICS CONSTANT VOLUME - 4 - PIPE INDUCTION




## AIR SYSTEM SCHEMATICS VARIABLE VOLUME - VAV







## AIR SYSTEM SCHEMATICS VARIABLE VOLUME - V.A.V. REHEAT




## AIR SYSTEM SCHEMATICS VARIABLE VOLUME - SERIES MIXING BOX




## AIR SYSTEM SCHEMATICS VARIABLE VOLUME - PARALLEL MIXING BOX




## AIR SYSTEM SCHEMATICS VARIABLE VOLUME - DUAL DUCT V.A.V.



## AIR SYSTEM SCHEMATICS VARIABLE VOLUME - 2- FAN DUAL DUCT V.A.V.




## AIR SYSTEM SCHEMATICS PTAC TERMINALS WITH DIRECT VENTILATION







## AIR SYSTEM SCHEMATICS PTAC TERMINALS WITH CENTRAL VENTILATION




## AIR SYSTEM SCHEMATICS 2 PIPE FAN COILS WITH DIRECT VENTILATION




## AIR SYSTEM SCHEMATICS 2 PIPE FAN COILS WITH CENTRAL VENTILATION




## AIR SYSTEM SCHEMATICS 4 PIPE FAN COILS WITH DIRECT VENTILATION



## AIR SYSTEM SCHEMATICS 4 PIPE FAN COILS WITH CENTRAL VENTILATION



## AIR SYSTEM SCHEMATICS WATER SOURCE H.P. WITH DIRECT VENTILATION





## AIR SYSTEM SCHEMATICS WATER SOURCE H.P. WITH CENTRAL VENTILATION

